

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for

PORTTYPECO	CITYTOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	MPLECOMME
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	001F	PRINCIPAL'S OFFICE	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	001F	PRINCIPAL'S OFFICE	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	001P	PRINCIPAL'S OFFICE	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	001P	PRINCIPAL'S OFFICE	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	004F	CLASSROOM FAUCET ROOM 115A	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	004F	CLASSROOM FAUCET ROOM 115A	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	004F	CLASSROOM FAUCET ROOM 115A	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	004F	CLASSROOM FAUCET ROOM 115A	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	004P	CLASSROOM FAUCET ROOM 115A	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	004P	CLASSROOM FAUCET ROOM 115A	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	005P	BUBBLER ROOM 115A	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	005P	BUBBLER ROOM 115A	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	006F	RM 115B	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	006F	RM 115B	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	006P	RM 115B	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	006P	CLASSROOM FAUCET ROOM 115B	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	006P	RM 115B	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	006P	CLASSROOM FAUCET ROOM 115B	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	008F	CLASSROOM FAUCET BACK ROOM 125	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	008F	CLASSROOM FAUCET BACK ROOM 125	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	008P	CLASSROOM FAUCET BACK ROOM 125	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	008P	CLASSROOM FAUCET BACK ROOM 125	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	010F	KITCHEN FAUCET	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	010F	KITCHEN FAUCET	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	010P	KITCHEN FAUCET	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	010P	KITCHEN FAUCET	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	011F	CLASSROOM FAUCET ROOM 110	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	011F	CLASSROOM FAUCET ROOM 110	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	011P	CLASSROOM FAUCET ROOM 110	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	011P	CLASSROOM FAUCET ROOM 110	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	013P	2ND FLOOR HALL BOTTLE FILLER	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	013P	2ND FLOOR HALL BOTTLE FILLER	

LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	028P	CLASSROOM FAUCET ROOM 201	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	030F	RM 101	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	030F	RM 101	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	030P	RM 101	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	030P	RM 101	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	032F	TEACHER'S LOUNGE	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	032F	TEACHER'S LOUNGE	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	032P	TEACHER'S LOUNGE	
LCCA	Brockton	00440400	Brockton: Goddard Alternative School	Public School	032P	TEACHER'S LOUNGE	

or copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

ANALYTENAME	RESULT	UNITS OF MEASURE	THRESHOLD DETECTION LIMIT	ANALYTICAL METHOD	ANALYSIS LAB	LAB SAMPLE ID	ANALYSIS COMMENTS
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-002	
COPPER	0.061	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-002	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-001	
COPPER	0.041	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-001	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-037	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-004	
COPPER	0.072	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-004	
COPPER	0.068	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-037	
LEAD	0.0025	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-003	
COPPER	0.078	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-003	
LEAD	0.020	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-005	
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-005	
LEAD	0.0016	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1701-00425-002	
COPPER	0.072	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1701-00425-002	
LEAD	0.0063	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1701-00425-001	
LEAD	0.0054	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-006	
COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1701-00425-001	
COPPER	0.073	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-006	
LEAD	0.0069	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-009	
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-009	
LEAD	0.043	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-008	
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-008	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-011	
COPPER	0.078	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-011	
LEAD	0.0020	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-010	
COPPER	0.062	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-010	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-013	
COPPER	0.068	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-013	
LEAD	0.011	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-012	
COPPER	0.085	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-012	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-014	
COPPER	0.089	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-014	

LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-016	
COPPER	0.046	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-016	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-015	
COPPER	0.060	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-015	
LEAD	0.0024	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-018	
COPPER	0.080	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-018	
LEAD	0.085	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-017	
COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-017	
LEAD	0.0015	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-020	
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-020	
LEAD	0.0023	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-019	
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-019	
LEAD	0.065	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-022	
COPPER	0.33	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-022	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-021	
COPPER	0.086	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-021	
LEAD	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-023	
COPPER	0.097	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-023	
LEAD	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-025	
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-025	
LEAD	0.0016	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-024	
COPPER	0.095	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-024	
LEAD	0.0014	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-026	
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-026	
LEAD	0.036	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-028	
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-028	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-027	
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-027	
LEAD	0.0027	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-030	
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-030	
LEAD	0.0089	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-029	
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-029	
LEAD	0.0044	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-032	
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-032	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-031	

COPPER	0.094	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-031	
LEAD	0.0072	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-034	
COPPER	0.076	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-034	
LEAD	0.0010	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-033	
COPPER	0.074	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-033	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-036	
COPPER	0.068	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-036	
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-035	
COPPER	0.070	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-29341-035	

SAMPLER NAME	SAMPLE COLLECTION DATE	TIME COLLECTION	REPORT DATE
EARL NOCON	12/3/2016	09:45:00	26-Jan-17
EARL NOCON	12/3/2016	09:45:00	26-Jan-17
EARL NOCON	12/3/2016	09:44:00	26-Jan-17
EARL NOCON	12/3/2016	09:44:00	26-Jan-17
EARL NOCON	12/3/2016	09:55:00	26-Jan-17
EARL NOCON	12/3/2016	09:57:00	26-Jan-17
EARL NOCON	12/3/2016	09:57:00	26-Jan-17
EARL NOCON	12/3/2016	09:55:00	26-Jan-17
EARL NOCON	12/3/2016	09:54:00	26-Jan-17
EARL NOCON	12/3/2016	09:54:00	26-Jan-17
EARL NOCON	12/3/2016	09:54:00	26-Jan-17
EARL NOCON	12/3/2016	09:54:00	26-Jan-17
JIM WILLETT	12/23/2016	06:05:00	16-Jan-17
JIM WILLETT	12/23/2016	06:05:00	16-Jan-17
JIM WILLETT	12/23/2016	06:04:00	16-Jan-17
EARL NOCON	12/3/2016	09:56:00	26-Jan-17
JIM WILLETT	12/23/2016	06:04:00	16-Jan-17
EARL NOCON	12/3/2016	09:56:00	26-Jan-17
EARL NOCON	12/3/2016	10:02:00	26-Jan-17
EARL NOCON	12/3/2016	10:02:00	26-Jan-17
EARL NOCON	12/3/2016	10:01:00	26-Jan-17
EARL NOCON	12/3/2016	10:01:00	26-Jan-17
EARL NOCON	12/3/2016	10:08:00	26-Jan-17
EARL NOCON	12/3/2016	10:08:00	26-Jan-17
EARL NOCON	12/3/2016	10:07:00	26-Jan-17
EARL NOCON	12/3/2016	10:07:00	26-Jan-17
EARL NOCON	12/3/2016	10:13:00	26-Jan-17
EARL NOCON	12/3/2016	10:13:00	26-Jan-17
EARL NOCON	12/3/2016	10:12:00	26-Jan-17
EARL NOCON	12/3/2016	10:12:00	26-Jan-17
EARL NOCON	12/3/2016	10:15:00	26-Jan-17
EARL NOCON	12/3/2016	10:15:00	26-Jan-17

EARL NOCON	12/3/2016	10:16:00	26-Jan-17
EARL NOCON	12/3/2016	10:16:00	26-Jan-17
EARL NOCON	12/3/2016	10:15:00	26-Jan-17
EARL NOCON	12/3/2016	10:15:00	26-Jan-17
EARL NOCON	12/3/2016	10:20:00	26-Jan-17
EARL NOCON	12/3/2016	10:20:00	26-Jan-17
EARL NOCON	12/3/2016	10:19:00	26-Jan-17
EARL NOCON	12/3/2016	10:19:00	26-Jan-17
EARL NOCON	12/3/2016	10:25:00	26-Jan-17
EARL NOCON	12/3/2016	10:25:00	26-Jan-17
EARL NOCON	12/3/2016	10:24:00	26-Jan-17
EARL NOCON	12/3/2016	10:24:00	26-Jan-17
EARL NOCON	12/3/2016	10:42:00	26-Jan-17
EARL NOCON	12/3/2016	10:42:00	26-Jan-17
EARL NOCON	12/3/2016	10:41:00	26-Jan-17
EARL NOCON	12/3/2016	10:41:00	26-Jan-17
EARL NOCON	12/3/2016	10:41:00	26-Jan-17
EARL NOCON	12/3/2016	10:41:00	26-Jan-17
EARL NOCON	12/3/2016	10:46:00	26-Jan-17
EARL NOCON	12/3/2016	10:46:00	26-Jan-17
EARL NOCON	12/3/2016	10:45:00	26-Jan-17
EARL NOCON	12/3/2016	10:45:00	26-Jan-17
EARL NOCON	12/3/2016	10:45:00	26-Jan-17
EARL NOCON	12/3/2016	10:45:00	26-Jan-17
EARL NOCON	12/3/2016	10:48:00	26-Jan-17
EARL NOCON	12/3/2016	10:48:00	26-Jan-17
EARL NOCON	12/3/2016	10:47:00	26-Jan-17
EARL NOCON	12/3/2016	10:47:00	26-Jan-17
EARL NOCON	12/3/2016	10:34:00	26-Jan-17
EARL NOCON	12/3/2016	10:34:00	26-Jan-17
EARL NOCON	12/3/2016	10:33:00	26-Jan-17
EARL NOCON	12/3/2016	10:33:00	26-Jan-17
EARL NOCON	12/3/2016	10:36:00	26-Jan-17
EARL NOCON	12/3/2016	10:36:00	26-Jan-17
EARL NOCON	12/3/2016	10:35:00	26-Jan-17

EARL NOCON	12/3/2016	10:35:00	26-Jan-17
EARL NOCON	12/3/2016	09:52:00	26-Jan-17
EARL NOCON	12/3/2016	09:52:00	26-Jan-17
EARL NOCON	12/3/2016	09:51:00	26-Jan-17
EARL NOCON	12/3/2016	09:51:00	26-Jan-17
EARL NOCON	12/3/2016	11:01:00	26-Jan-17
EARL NOCON	12/3/2016	11:01:00	26-Jan-17
EARL NOCON	12/3/2016	11:00:00	26-Jan-17
EARL NOCON	12/3/2016	11:00:00	26-Jan-17