

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is an

PORTYPECO	CITYTOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	PLECOMM	ANALYTENAME	RESULT
LCCA	Brockton	00440045	Brockton: Hancock	Public School	001F	FAUCET ROOM 16		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	001F	FAUCET ROOM 16		COPPER	0.038
LCCA	Brockton	00440045	Brockton: Hancock	Public School	001P	FAUCET ROOM 16		LEAD	0.0050
LCCA	Brockton	00440045	Brockton: Hancock	Public School	001P	FAUCET ROOM 16		COPPER	0.10
LCCA	Brockton	00440045	Brockton: Hancock	Public School	002P	BUBBLER ROOM 16		LEAD	0.0070
LCCA	Brockton	00440045	Brockton: Hancock	Public School	002P	BUBBLER ROOM 16		COPPER	0.11
LCCA	Brockton	00440045	Brockton: Hancock	Public School	003F	FAUCET ROOM 17		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	003F	FAUCET ROOM 17		COPPER	0.060
LCCA	Brockton	00440045	Brockton: Hancock	Public School	003P	FAUCET ROOM 17		LEAD	0.0079
LCCA	Brockton	00440045	Brockton: Hancock	Public School	003P	FAUCET ROOM 17		COPPER	0.098
LCCA	Brockton	00440045	Brockton: Hancock	Public School	004P	BUBBLER ROOM 17		LEAD	0.0040
LCCA	Brockton	00440045	Brockton: Hancock	Public School	004P	BUBBLER ROOM 17		COPPER	0.045
LCCA	Brockton	00440045	Brockton: Hancock	Public School	005F	KITCHEN KETTLE COLD		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	005F	KITCHEN KETTLE COLD		COPPER	0.089
LCCA	Brockton	00440045	Brockton: Hancock	Public School	005P	KITCHEN KETTLE COLD		LEAD	0.0040
LCCA	Brockton	00440045	Brockton: Hancock	Public School	005P	KITCHEN KETTLE COLD		COPPER	0.040
LCCA	Brockton	00440045	Brockton: Hancock	Public School	006F	KITCHEN PREP SINK WITH TRAY		LEAD	0.011
LCCA	Brockton	00440045	Brockton: Hancock	Public School	006F	KITCHEN PREP SINK WITH TRAY		COPPER	0.16
LCCA	Brockton	00440045	Brockton: Hancock	Public School	006P	KITCHEN PREP SINK WITH TRAY		LEAD	0.10
LCCA	Brockton	00440045	Brockton: Hancock	Public School	006P	KITCHEN PREP SINK WITH TRAY		COPPER	0.84
LCCA	Brockton	00440045	Brockton: Hancock	Public School	007F	KITCHEN PREP SINK		LEAD	0.0017
LCCA	Brockton	00440045	Brockton: Hancock	Public School	007F	KITCHEN PREP SINK		COPPER	0.17
LCCA	Brockton	00440045	Brockton: Hancock	Public School	007P	KITCHEN PREP SINK		LEAD	0.0042

LCCA	Brockton	00440045	Brockton: Hancock	Public School	007P	KITCHEN PREP SINK		COPPER	0.30
LCCA	Brockton	00440045	Brockton: Hancock	Public School	008F	OUTSIDE BOYS GANG		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	008F	OUTSIDE BOYS GANG		COPPER	0.050
LCCA	Brockton	00440045	Brockton: Hancock	Public School	008P	OUTSIDE BOYS GANG		LEAD	0.0029
LCCA	Brockton	00440045	Brockton: Hancock	Public School	008P	OUTSIDE BOYS GANG		COPPER	0.082
LCCA	Brockton	00440045	Brockton: Hancock	Public School	010F	CLASSROOM FAUCET ROOM 25		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	010F	CLASSROOM FAUCET ROOM 25		COPPER	0.11
LCCA	Brockton	00440045	Brockton: Hancock	Public School	010P	CLASSROOM FAUCET ROOM 25		LEAD	0.0084
LCCA	Brockton	00440045	Brockton: Hancock	Public School	010P	CLASSROOM FAUCET ROOM 25		COPPER	0.16
LCCA	Brockton	00440045	Brockton: Hancock	Public School	012F	CLASSROOM FAUCET ROOM 18		LEAD	0.0068
LCCA	Brockton	00440045	Brockton: Hancock	Public School	012F	CLASSROOM FAUCET ROOM 18		COPPER	0.21
LCCA	Brockton	00440045	Brockton: Hancock	Public School	012P	CLASSROOM FAUCET ROOM 18		LEAD	0.34
LCCA	Brockton	00440045	Brockton: Hancock	Public School	012P	CLASSROOM FAUCET ROOM 18		COPPER	1.8
LCCA	Brockton	00440045	Brockton: Hancock	Public School	013P	BUBBLER ROOM 18		LEAD	0.098
LCCA	Brockton	00440045	Brockton: Hancock	Public School	013P	BUBBLER ROOM 18		COPPER	0.28
LCCA	Brockton	00440045	Brockton: Hancock	Public School	014F	CLASSROOM FAUCET ROOM 19		LEAD	0.0061
LCCA	Brockton	00440045	Brockton: Hancock	Public School	014F	CLASSROOM FAUCET ROOM 19		COPPER	0.22
LCCA	Brockton	00440045	Brockton: Hancock	Public School	014P	CLASSROOM FAUCET ROOM 19		LEAD	0.022
LCCA	Brockton	00440045	Brockton: Hancock	Public School	014P	CLASSROOM FAUCET ROOM 19		COPPER	0.14
LCCA	Brockton	00440045	Brockton: Hancock	Public School	016F	CLASSROOM FAUCET ROOM 23		LEAD	0.0061
LCCA	Brockton	00440045	Brockton: Hancock	Public School	016F	CLASSROOM FAUCET ROOM 23		COPPER	0.38
LCCA	Brockton	00440045	Brockton: Hancock	Public School	016P	CLASSROOM FAUCET ROOM 23		LEAD	0.15
LCCA	Brockton	00440045	Brockton: Hancock	Public School	016P	CLASSROOM FAUCET ROOM 23		COPPER	0.88
LCCA	Brockton	00440045	Brockton: Hancock	Public School	018F	CLASSROOM FAUCET ROOM 22		LEAD	0.0027
LCCA	Brockton	00440045	Brockton: Hancock	Public School	018F	CLASSROOM FAUCET ROOM 22		COPPER	0.33

LCCA	Brockton	00440045	Brockton: Hancock	Public School	018P	CLASSROOM FAUCET ROOM 22		LEAD	0.20
LCCA	Brockton	00440045	Brockton: Hancock	Public School	018P	CLASSROOM FAUCET ROOM 22		COPPER	0.83
LCCA	Brockton	00440045	Brockton: Hancock	Public School	019P	BUBBLER ROOM 22		LEAD	0.098
LCCA	Brockton	00440045	Brockton: Hancock	Public School	019P	BUBBLER ROOM 22		COPPER	0.39
LCCA	Brockton	00440045	Brockton: Hancock	Public School	020F	CLASSROOM FAUCET ROOM 20		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	020F	CLASSROOM FAUCET ROOM 20		COPPER	0.14
LCCA	Brockton	00440045	Brockton: Hancock	Public School	020P	CLASSROOM FAUCET ROOM 20		LEAD	0.0068
LCCA	Brockton	00440045	Brockton: Hancock	Public School	020P	CLASSROOM FAUCET ROOM 20		COPPER	0.16
LCCA	Brockton	00440045	Brockton: Hancock	Public School	022F	CLASSROOM FAUCET ROOM 21		LEAD	0.0050
LCCA	Brockton	00440045	Brockton: Hancock	Public School	022F	CLASSROOM FAUCET ROOM 21		COPPER	0.44
LCCA	Brockton	00440045	Brockton: Hancock	Public School	022P	CLASSROOM FAUCET ROOM 21		LEAD	0.010
LCCA	Brockton	00440045	Brockton: Hancock	Public School	022P	CLASSROOM FAUCET ROOM 21		COPPER	0.36
LCCA	Brockton	00440045	Brockton: Hancock	Public School	023P	BUBBLER ROOM 21		LEAD	0.0089
LCCA	Brockton	00440045	Brockton: Hancock	Public School	023P	BUBBLER ROOM 21		COPPER	0.19
LCCA	Brockton	00440045	Brockton: Hancock	Public School	024F	BUBBLER OUTSIDE BOYS GANG ADUL		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	024F	BUBBLER OUTSIDE BOYS GANG ADUL		COPPER	0.082
LCCA	Brockton	00440045	Brockton: Hancock	Public School	024P	BUBBLER OUTSIDE BOYS GANG ADUL		LEAD	0.0014
LCCA	Brockton	00440045	Brockton: Hancock	Public School	024P	BUBBLER OUTSIDE BOYS GANG ADUL		COPPER	0.086
LCCA	Brockton	00440045	Brockton: Hancock	Public School	025P	BUBBLER OUTSIDE BOYS GANG CHIL		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	025P	BUBBLER OUTSIDE BOYS GANG CHIL		COPPER	0.10
LCCA	Brockton	00440045	Brockton: Hancock	Public School	027F	FAUCET COPY RM NEXT TO LIBRARY		LEAD	0.011
LCCA	Brockton	00440045	Brockton: Hancock	Public School	027F	FAUCET COPY RM NEXT TO LIBRARY		COPPER	0.14
LCCA	Brockton	00440045	Brockton: Hancock	Public School	027P	FAUCET COPY RM NEXT TO LIBRARY		LEAD	0.73
LCCA	Brockton	00440045	Brockton: Hancock	Public School	027P	FAUCET COPY RM NEXT TO LIBRARY		COPPER	6.3
LCCA	Brockton	00440045	Brockton: Hancock	Public School	028F	CLASSROOM FAUCET ROOM K1		LEAD	0.013

LCCA	Brockton	00440045	Brockton: Hancock	Public School	028F	CLASSROOM FAUCET ROOM K1		COPPER	0.14
LCCA	Brockton	00440045	Brockton: Hancock	Public School	028P	CLASSROOM FAUCET ROOM K1		LEAD	0.0058
LCCA	Brockton	00440045	Brockton: Hancock	Public School	028P	CLASSROOM FAUCET ROOM K1		COPPER	0.18
LCCA	Brockton	00440045	Brockton: Hancock	Public School	030F	FAUCET TEACHER'S LOUNGE		LEAD	0.0013
LCCA	Brockton	00440045	Brockton: Hancock	Public School	030F	FAUCET TEACHER'S LOUNGE		COPPER	0.13
LCCA	Brockton	00440045	Brockton: Hancock	Public School	030P	FAUCET TEACHER'S LOUNGE		LEAD	0.0062
LCCA	Brockton	00440045	Brockton: Hancock	Public School	030P	FAUCET TEACHER'S LOUNGE		COPPER	0.40
LCCA	Brockton	00440045	Brockton: Hancock	Public School	031F	CLASSROOM FAUCET ROOM 27		LEAD	0.043
LCCA	Brockton	00440045	Brockton: Hancock	Public School	031F	CLASSROOM FAUCET ROOM 27		COPPER	0.34
LCCA	Brockton	00440045	Brockton: Hancock	Public School	031P	CLASSROOM FAUCET ROOM 27		LEAD	1.1
LCCA	Brockton	00440045	Brockton: Hancock	Public School	031P	CLASSROOM FAUCET ROOM 27		COPPER	4.1
LCCA	Brockton	00440045	Brockton: Hancock	Public School	032P	BUBBLER ROOM 27		LEAD	0.14
LCCA	Brockton	00440045	Brockton: Hancock	Public School	032P	BUBBLER ROOM 27		COPPER	0.56
LCCA	Brockton	00440045	Brockton: Hancock	Public School	033F	CLASSROOM FAUCET ROOM K2		LEAD	0.016
LCCA	Brockton	00440045	Brockton: Hancock	Public School	033F	CLASSROOM FAUCET ROOM K2		COPPER	0.30
LCCA	Brockton	00440045	Brockton: Hancock	Public School	033P	CLASSROOM FAUCET ROOM K2		LEAD	0.57
LCCA	Brockton	00440045	Brockton: Hancock	Public School	033P	CLASSROOM FAUCET ROOM K2		COPPER	8.7
LCCA	Brockton	00440045	Brockton: Hancock	Public School	035F	CLASSROOM FAUCET ROOM 28		LEAD	0.025
LCCA	Brockton	00440045	Brockton: Hancock	Public School	035F	CLASSROOM FAUCET ROOM 28		COPPER	1.8
LCCA	Brockton	00440045	Brockton: Hancock	Public School	035P	CLASSROOM FAUCET ROOM 28		LEAD	0.24
LCCA	Brockton	00440045	Brockton: Hancock	Public School	035P	CLASSROOM FAUCET ROOM 28		COPPER	15.3
LCCA	Brockton	00440045	Brockton: Hancock	Public School	037F	CLASSROOM FAUCET ROOM 29		LEAD	0.011
LCCA	Brockton	00440045	Brockton: Hancock	Public School	037F	CLASSROOM FAUCET ROOM 29		COPPER	1.7
LCCA	Brockton	00440045	Brockton: Hancock	Public School	037P	CLASSROOM FAUCET ROOM 29		LEAD	0.057
LCCA	Brockton	00440045	Brockton: Hancock	Public School	037P	CLASSROOM FAUCET ROOM 29		COPPER	1.6

LCCA	Brockton	00440045	Brockton: Hancock	Public School	039F	CLASSROOM FAUCET ROOM 30		LEAD	0.016
LCCA	Brockton	00440045	Brockton: Hancock	Public School	039F	CLASSROOM FAUCET ROOM 30		COPPER	0.39
LCCA	Brockton	00440045	Brockton: Hancock	Public School	039P	CLASSROOM FAUCET ROOM 30		LEAD	0.067
LCCA	Brockton	00440045	Brockton: Hancock	Public School	039P	CLASSROOM FAUCET ROOM 30		COPPER	0.45
LCCA	Brockton	00440045	Brockton: Hancock	Public School	040P	BUBBLER ROOM 30		LEAD	0.014
LCCA	Brockton	00440045	Brockton: Hancock	Public School	040P	BUBBLER ROOM 30		COPPER	0.48
LCCA	Brockton	00440045	Brockton: Hancock	Public School	043F	BUBBLER HALLWAY ADULT		LEAD	0.0028
LCCA	Brockton	00440045	Brockton: Hancock	Public School	043F	BUBBLER HALLWAY ADULT		COPPER	0.22
LCCA	Brockton	00440045	Brockton: Hancock	Public School	043P	BUBBLER HALLWAY ADULT		LEAD	0.0085
LCCA	Brockton	00440045	Brockton: Hancock	Public School	043P	BUBBLER HALLWAY ADULT		COPPER	0.22
LCCA	Brockton	00440045	Brockton: Hancock	Public School	044P	BUBBLER HALLWAY CHILD/ADA		LEAD	0.0059
LCCA	Brockton	00440045	Brockton: Hancock	Public School	044P	BUBBLER HALLWAY CHILD/ADA		COPPER	0.19
LCCA	Brockton	00440045	Brockton: Hancock	Public School	045F	CLASSROOM FAUCET ROOM 31		LEAD	0.021
LCCA	Brockton	00440045	Brockton: Hancock	Public School	045F	CLASSROOM FAUCET ROOM 31		COPPER	0.24
LCCA	Brockton	00440045	Brockton: Hancock	Public School	045P	CLASSROOM FAUCET ROOM 31		LEAD	0.41
LCCA	Brockton	00440045	Brockton: Hancock	Public School	045P	CLASSROOM FAUCET ROOM 31		COPPER	0.89
LCCA	Brockton	00440045	Brockton: Hancock	Public School	047F	CLASSROOM FAUCET ROOM 1		LEAD	0.0058
LCCA	Brockton	00440045	Brockton: Hancock	Public School	047F	CLASSROOM FAUCET ROOM 1		COPPER	0.14
LCCA	Brockton	00440045	Brockton: Hancock	Public School	047P	CLASSROOM FAUCET ROOM 1		LEAD	0.044
LCCA	Brockton	00440045	Brockton: Hancock	Public School	047P	CLASSROOM FAUCET ROOM 1		COPPER	0.82
LCCA	Brockton	00440045	Brockton: Hancock	Public School	049F	CLASSROOM FAUCET ROOM 2		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	049F	CLASSROOM FAUCET ROOM 2		COPPER	0.040
LCCA	Brockton	00440045	Brockton: Hancock	Public School	049P	CLASSROOM FAUCET ROOM 2		LEAD	0.044
LCCA	Brockton	00440045	Brockton: Hancock	Public School	049P	CLASSROOM FAUCET ROOM 2		COPPER	0.27
LCCA	Brockton	00440045	Brockton: Hancock	Public School	050P	BUBBLER ROOM 2		LEAD	0.022

LCCA	Brockton	00440045	Brockton: Hancock	Public School	050P	BUBBLER ROOM 2		COPPER	0.089
LCCA	Brockton	00440045	Brockton: Hancock	Public School	051F	FAUCET TEACHER'S LOUNGE		LEAD	0.0029
LCCA	Brockton	00440045	Brockton: Hancock	Public School	051F	FAUCET TEACHER'S LOUNGE		COPPER	0.068
LCCA	Brockton	00440045	Brockton: Hancock	Public School	051P	FAUCET TEACHER'S LOUNGE		LEAD	0.014
LCCA	Brockton	00440045	Brockton: Hancock	Public School	051P	FAUCET TEACHER'S LOUNGE		COPPER	0.12
LCCA	Brockton	00440045	Brockton: Hancock	Public School	052F	CLASSROOM FAUCET ROOM 15		LEAD	0.076
LCCA	Brockton	00440045	Brockton: Hancock	Public School	052F	CLASSROOM FAUCET ROOM 15		COPPER	0.26
LCCA	Brockton	00440045	Brockton: Hancock	Public School	052P	CLASSROOM FAUCET ROOM 15		LEAD	2.76
LCCA	Brockton	00440045	Brockton: Hancock	Public School	052P	CLASSROOM FAUCET ROOM 15		COPPER	15.6
LCCA	Brockton	00440045	Brockton: Hancock	Public School	053P	BUBBLER ROOM 15		LEAD	32.4
LCCA	Brockton	00440045	Brockton: Hancock	Public School	053P	BUBBLER ROOM 15		COPPER	8.24
LCCA	Brockton	00440045	Brockton: Hancock	Public School	054F	CLASSROOM FAUCET ROOM 14		LEAD	0.0048
LCCA	Brockton	00440045	Brockton: Hancock	Public School	054F	CLASSROOM FAUCET ROOM 14		COPPER	0.12
LCCA	Brockton	00440045	Brockton: Hancock	Public School	054P	CLASSROOM FAUCET ROOM 14		LEAD	0.029
LCCA	Brockton	00440045	Brockton: Hancock	Public School	054P	CLASSROOM FAUCET ROOM 14		COPPER	0.52
LCCA	Brockton	00440045	Brockton: Hancock	Public School	056F	CLASSROOM FAUCET ROOM 3		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	056F	CLASSROOM FAUCET ROOM 3		COPPER	0.053
LCCA	Brockton	00440045	Brockton: Hancock	Public School	056P	CLASSROOM FAUCET ROOM 3		LEAD	0.0020
LCCA	Brockton	00440045	Brockton: Hancock	Public School	056P	CLASSROOM FAUCET ROOM 3		COPPER	0.071
LCCA	Brockton	00440045	Brockton: Hancock	Public School	057P	BUBBLER ROOM 3		LEAD	0.0074
LCCA	Brockton	00440045	Brockton: Hancock	Public School	057P	BUBBLER ROOM 3		COPPER	0.090
LCCA	Brockton	00440045	Brockton: Hancock	Public School	058F	CLASSROOM FAUCET ROOM 4		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	058F	CLASSROOM FAUCET ROOM 4		COPPER	0.046
LCCA	Brockton	00440045	Brockton: Hancock	Public School	058P	CLASSROOM FAUCET ROOM 4		LEAD	0.0020
LCCA	Brockton	00440045	Brockton: Hancock	Public School	058P	CLASSROOM FAUCET ROOM 4		COPPER	0.055

LCCA	Brockton	00440045	Brockton: Hancock	Public School	059P	BUBBLER ROOM 4		LEAD	0.0024
LCCA	Brockton	00440045	Brockton: Hancock	Public School	059P	BUBBLER ROOM 4		COPPER	0.11
LCCA	Brockton	00440045	Brockton: Hancock	Public School	060F	BUBBLER HALL BY GANG BATHROOMS		LEAD	0.0072
LCCA	Brockton	00440045	Brockton: Hancock	Public School	060F	BUBBLER HALL BY GANG BATHROOMS		COPPER	0.070
LCCA	Brockton	00440045	Brockton: Hancock	Public School	060P	BUBBLER HALL BY GANG BATHROOMS		LEAD	0.018
LCCA	Brockton	00440045	Brockton: Hancock	Public School	060P	BUBBLER HALL BY GANG BATHROOMS		COPPER	0.12
LCCA	Brockton	00440045	Brockton: Hancock	Public School	062F	CLASSROOM FAUCET ROOM 13		LEAD	0.024
LCCA	Brockton	00440045	Brockton: Hancock	Public School	062F	CLASSROOM FAUCET ROOM 13		COPPER	0.25
LCCA	Brockton	00440045	Brockton: Hancock	Public School	062P	CLASSROOM FAUCET ROOM 13		LEAD	3.55
LCCA	Brockton	00440045	Brockton: Hancock	Public School	062P	CLASSROOM FAUCET ROOM 13		COPPER	30.9
LCCA	Brockton	00440045	Brockton: Hancock	Public School	063P	BUBBLER ROOM 13		LEAD	0.66
LCCA	Brockton	00440045	Brockton: Hancock	Public School	063P	BUBBLER ROOM 13		COPPER	6.2
LCCA	Brockton	00440045	Brockton: Hancock	Public School	064F	CLASSROOM FAUCET ROOM 12		LEAD	0.0083
LCCA	Brockton	00440045	Brockton: Hancock	Public School	064F	CLASSROOM FAUCET ROOM 12		COPPER	0.092
LCCA	Brockton	00440045	Brockton: Hancock	Public School	064P	CLASSROOM FAUCET ROOM 12		LEAD	0.040
LCCA	Brockton	00440045	Brockton: Hancock	Public School	064P	CLASSROOM FAUCET ROOM 12		COPPER	0.24
LCCA	Brockton	00440045	Brockton: Hancock	Public School	065P	BUBBLER ROOM 12		LEAD	0.0036
LCCA	Brockton	00440045	Brockton: Hancock	Public School	065P	BUBBLER ROOM 12		COPPER	0.079
LCCA	Brockton	00440045	Brockton: Hancock	Public School	066F	CLASSROOM FAUCET ROOM 5		LEAD	0.035
LCCA	Brockton	00440045	Brockton: Hancock	Public School	066F	CLASSROOM FAUCET ROOM 5		COPPER	0.21
LCCA	Brockton	00440045	Brockton: Hancock	Public School	066P	CLASSROOM FAUCET ROOM 5		LEAD	1.2
LCCA	Brockton	00440045	Brockton: Hancock	Public School	066P	CLASSROOM FAUCET ROOM 5		COPPER	2.6
LCCA	Brockton	00440045	Brockton: Hancock	Public School	068F	CLASSROOM FAUCET ROOM 6		LEAD	0.0041
LCCA	Brockton	00440045	Brockton: Hancock	Public School	068F	CLASSROOM FAUCET ROOM 6		COPPER	0.071
LCCA	Brockton	00440045	Brockton: Hancock	Public School	068P	CLASSROOM FAUCET ROOM 6		LEAD	0.17

LCCA	Brockton	00440045	Brockton: Hancock	Public School	068P	CLASSROOM FAUCET ROOM 6		COPPER	0.42
LCCA	Brockton	00440045	Brockton: Hancock	Public School	069P	BUBBLER ROOM 6		LEAD	0.048
LCCA	Brockton	00440045	Brockton: Hancock	Public School	069P	BUBBLER ROOM 6		COPPER	0.16
LCCA	Brockton	00440045	Brockton: Hancock	Public School	070F	CLASSROOM FAUCET ROOM 11		LEAD	0.021
LCCA	Brockton	00440045	Brockton: Hancock	Public School	070F	CLASSROOM FAUCET ROOM 11		COPPER	0.34
LCCA	Brockton	00440045	Brockton: Hancock	Public School	070P	CLASSROOM FAUCET ROOM 11		LEAD	0.15
LCCA	Brockton	00440045	Brockton: Hancock	Public School	070P	CLASSROOM FAUCET ROOM 11		COPPER	0.54
LCCA	Brockton	00440045	Brockton: Hancock	Public School	071P	BUBBLER ROOM 11		LEAD	0.039
LCCA	Brockton	00440045	Brockton: Hancock	Public School	071P	BUBBLER ROOM 11		COPPER	0.12
LCCA	Brockton	00440045	Brockton: Hancock	Public School	072F	CLASSROOM FAUCET ROOM 10		LEAD	0.0090
LCCA	Brockton	00440045	Brockton: Hancock	Public School	072F	CLASSROOM FAUCET ROOM 10		COPPER	0.079
LCCA	Brockton	00440045	Brockton: Hancock	Public School	072P	CLASSROOM FAUCET ROOM 10		LEAD	0.13
LCCA	Brockton	00440045	Brockton: Hancock	Public School	072P	CLASSROOM FAUCET ROOM 10		COPPER	0.16
LCCA	Brockton	00440045	Brockton: Hancock	Public School	073P	BUBBLER ROOM 10		LEAD	0.018
LCCA	Brockton	00440045	Brockton: Hancock	Public School	073P	BUBBLER ROOM 10		COPPER	0.18
LCCA	Brockton	00440045	Brockton: Hancock	Public School	074F	CLASSROOM FAUCET ROOM 7		LEAD	0.0038
LCCA	Brockton	00440045	Brockton: Hancock	Public School	074F	CLASSROOM FAUCET ROOM 7		COPPER	0.27
LCCA	Brockton	00440045	Brockton: Hancock	Public School	074P	CLASSROOM FAUCET ROOM 7		LEAD	0.053
LCCA	Brockton	00440045	Brockton: Hancock	Public School	074P	CLASSROOM FAUCET ROOM 7		COPPER	1.4
LCCA	Brockton	00440045	Brockton: Hancock	Public School	076F	CLASSROOM FAUCET ROOM 8		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	076F	CLASSROOM FAUCET ROOM 8		COPPER	0.29
LCCA	Brockton	00440045	Brockton: Hancock	Public School	076P	CLASSROOM FAUCET ROOM 8		LEAD	0.0033
LCCA	Brockton	00440045	Brockton: Hancock	Public School	076P	CLASSROOM FAUCET ROOM 8		COPPER	0.23
LCCA	Brockton	00440045	Brockton: Hancock	Public School	077P	BUBBLER ROOM 8		LEAD	0.0034
LCCA	Brockton	00440045	Brockton: Hancock	Public School	077P	BUBBLER ROOM 8		COPPER	0.26



LCCA	Brockton	00440045	Brockton: Hancock	Public School	078F	CLASSROOM FAUCET ROOM 9		LEAD	0.0019
LCCA	Brockton	00440045	Brockton: Hancock	Public School	078F	CLASSROOM FAUCET ROOM 9		COPPER	0.15
LCCA	Brockton	00440045	Brockton: Hancock	Public School	078P	CLASSROOM FAUCET ROOM 9		LEAD	0.042
LCCA	Brockton	00440045	Brockton: Hancock	Public School	078P	CLASSROOM FAUCET ROOM 9		COPPER	0.19
LCCA	Brockton	00440045	Brockton: Hancock	Public School	079P	BUBBLER ROOM 9		LEAD	0.14
LCCA	Brockton	00440045	Brockton: Hancock	Public School	079P	BUBBLER ROOM 9		COPPER	0.18
LCCA	Brockton	00440045	Brockton: Hancock	Public School	080F	NURSE'S OFF. SINK-TEMPER VALVE		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	080F	NURSE'S OFF. SINK-TEMPER VALVE		COPPER	0.067
LCCA	Brockton	00440045	Brockton: Hancock	Public School	080P	NURSE'S OFF. SINK-TEMPER VALVE		LEAD	0.0051
LCCA	Brockton	00440045	Brockton: Hancock	Public School	080P	NURSE'S OFF. SINK-TEMPER VALVE		COPPER	0.062
LCCA	Brockton	00440045	Brockton: Hancock	Public School	081F	CAFE BOTTLE FILLER		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	081F	CAFE BOTTLE FILLER		COPPER	0.088
LCCA	Brockton	00440045	Brockton: Hancock	Public School	081P	CAFE BOTTLE FILLER		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	081P	CAFE BOTTLE FILLER		COPPER	0.27
LCCA	Brockton	00440045	Brockton: Hancock	Public School	082P	BUBBLER CAFE		LEAD	ND
LCCA	Brockton	00440045	Brockton: Hancock	Public School	082P	BUBBLER CAFE		COPPER	0.27
LCCA	Brockton	00440045	Brockton: Hancock	Public School	083F	CLASSROOM FAUCET ROOM 24		LEAD	0.0018
LCCA	Brockton	00440045	Brockton: Hancock	Public School	083F	CLASSROOM FAUCET ROOM 24		COPPER	0.081
LCCA	Brockton	00440045	Brockton: Hancock	Public School	083P	CLASSROOM FAUCET ROOM 24		LEAD	0.019
LCCA	Brockton	00440045	Brockton: Hancock	Public School	083P	CLASSROOM FAUCET ROOM 24		COPPER	0.14
LCCA	Brockton	00440045	Brockton: Hancock	Public School	084P	BUBBLER ROOM 24		LEAD	0.0014
LCCA	Brockton	00440045	Brockton: Hancock	Public School	084P	BUBBLER ROOM 24		COPPER	0.16

any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

UNIT OF MEASURE	MDL DETECTION	ANALYTICAL METHOD	ANALYSIS LAB	LAB SAMPLE ID	ANALYSIS COMMENT	SAMPLER NAME	SAMPLE COLLECTION DATE	TIME COLLECTION	REPORT DATE
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-002		JIM WILLETT	11/19/2016	07:25:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-002		JIM WILLETT	11/19/2016	07:25:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-001		JIM WILLETT	11/19/2016	07:24:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-001		JIM WILLETT	11/19/2016	07:24:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-003		JIM WILLETT	11/19/2016	07:24:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-003		JIM WILLETT	11/19/2016	07:24:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-005		JIM WILLETT	11/19/2016	07:29:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-005		JIM WILLETT	11/19/2016	07:29:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-004		JIM WILLETT	11/19/2016	07:28:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-004		JIM WILLETT	11/19/2016	07:28:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-006		JIM WILLETT	11/19/2016	07:28:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-006		JIM WILLETT	11/19/2016	07:28:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-008		JIM WILLETT	11/19/2016	08:36:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-008		JIM WILLETT	11/19/2016	08:36:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-007		JIM WILLETT	11/19/2016	08:35:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-007		JIM WILLETT	11/19/2016	08:35:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-010		JIM WILLETT	11/19/2016	08:38:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-010		JIM WILLETT	11/19/2016	08:38:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-009		JIM WILLETT	11/19/2016	08:37:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-009		JIM WILLETT	11/19/2016	08:37:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-012		JIM WILLETT	11/19/2016	08:40:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-012		JIM WILLETT	11/19/2016	08:40:00	24-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28265-011		JIM WILLETT	11/19/2016	08:39:00	24-Jan-17

















