

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l

PORTTYPECO	CITYTOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME
LCCA	Brockton	00440055	Brockton: Huntington	Public School	001P	CLASSROOM FAUCET RM 116
LCCA	Brockton	00440055	Brockton: Huntington	Public School	001P	CLASSROOM FAUCET RM 116
LCCA	Brockton	00440055	Brockton: Huntington	Public School	002F	BUBBLER ROOM 116
LCCA	Brockton	00440055	Brockton: Huntington	Public School	002F	BUBBLER ROOM 116
LCCA	Brockton	00440055	Brockton: Huntington	Public School	002P	BUBBLER ROOM 116
LCCA	Brockton	00440055	Brockton: Huntington	Public School	002P	BUBBLER ROOM 116
LCCA	Brockton	00440055	Brockton: Huntington	Public School	003P	CLASSROOM FAUCET RM 115 & 114
LCCA	Brockton	00440055	Brockton: Huntington	Public School	003P	CLASSROOM FAUCET RM 115 & 114
LCCA	Brockton	00440055	Brockton: Huntington	Public School	004F	BUBBLER RM 115 & 114
LCCA	Brockton	00440055	Brockton: Huntington	Public School	004F	BUBBLER RM 115 & 114
LCCA	Brockton	00440055	Brockton: Huntington	Public School	004P	BUBBLER RM 115 & 114
LCCA	Brockton	00440055	Brockton: Huntington	Public School	004P	BUBBLER RM 115 & 114
LCCA	Brockton	00440055	Brockton: Huntington	Public School	005F	BUBBLER OUTSIDE OF GYM
LCCA	Brockton	00440055	Brockton: Huntington	Public School	005F	BUBBLER OUTSIDE OF GYM
LCCA	Brockton	00440055	Brockton: Huntington	Public School	005P	BUBBLER OUTSIDE OF GYM
LCCA	Brockton	00440055	Brockton: Huntington	Public School	005P	BUBBLER OUTSIDE OF GYM
LCCA	Brockton	00440055	Brockton: Huntington	Public School	006F	KITCHEN FAUCET KITCHEN
LCCA	Brockton	00440055	Brockton: Huntington	Public School	006F	KITCHEN FAUCET KITCHEN

LCCA	Brockton	00440055	Brockton: Huntington	Public School	006P	KITCHEN FAUCET KITCHEN
LCCA	Brockton	00440055	Brockton: Huntington	Public School	006P	KITCHEN FAUCET KITCHEN
LCCA	Brockton	00440055	Brockton: Huntington	Public School	007P	BOTTLE FILLER OUTSIDE KITCHEN
LCCA	Brockton	00440055	Brockton: Huntington	Public School	007P	BOTTLE FILLER OUTSIDE KITCHEN
LCCA	Brockton	00440055	Brockton: Huntington	Public School	008F	BUBBLER OUTSIDE OF KITCHEN
LCCA	Brockton	00440055	Brockton: Huntington	Public School	008F	BUBBLER OUTSIDE OF KITCHEN
LCCA	Brockton	00440055	Brockton: Huntington	Public School	008P	BUBBLER OUTSIDE OF KITCHEN
LCCA	Brockton	00440055	Brockton: Huntington	Public School	008P	BUBBLER OUTSIDE OF KITCHEN
LCCA	Brockton	00440055	Brockton: Huntington	Public School	009F	KITCHEN FAUCET TEACHER'S LOUNG
LCCA	Brockton	00440055	Brockton: Huntington	Public School	009F	KITCHEN FAUCET TEACHER'S LOUNG
LCCA	Brockton	00440055	Brockton: Huntington	Public School	009P	KITCHEN FAUCET TEACHER'S LOUNG
LCCA	Brockton	00440055	Brockton: Huntington	Public School	009P	KITCHEN FAUCET TEACHER'S LOUNG
LCCA	Brockton	00440055	Brockton: Huntington	Public School	011F	CLASSROOM FAUCET RM 104 & 103
LCCA	Brockton	00440055	Brockton: Huntington	Public School	011F	CLASSROOM FAUCET RM 104 & 103
LCCA	Brockton	00440055	Brockton: Huntington	Public School	011P	CLASSROOM FAUCET RM 104 & 103
LCCA	Brockton	00440055	Brockton: Huntington	Public School	011P	CLASSROOM FAUCET RM 104 & 103
LCCA	Brockton	00440055	Brockton: Huntington	Public School	013F	BUBBLER RM 117
LCCA	Brockton	00440055	Brockton: Huntington	Public School	013F	BUBBLER RM 117
LCCA	Brockton	00440055	Brockton: Huntington	Public School	013P	BUBBLER RM 117
LCCA	Brockton	00440055	Brockton: Huntington	Public School	013P	BUBBLER RM 117

LCCA	Brockton	00440055	Brockton: Huntington	Public School	014P	CLASSROOM FAUCET RM 117
LCCA	Brockton	00440055	Brockton: Huntington	Public School	014P	CLASSROOM FAUCET RM 117
LCCA	Brockton	00440055	Brockton: Huntington	Public School	015F	SINK NURSE'S OFFICE
LCCA	Brockton	00440055	Brockton: Huntington	Public School	015F	SINK NURSE'S OFFICE
LCCA	Brockton	00440055	Brockton: Huntington	Public School	015P	SINK NURSE'S OFFICE
LCCA	Brockton	00440055	Brockton: Huntington	Public School	015P	SINK NURSE'S OFFICE
LCCA	Brockton	00440055	Brockton: Huntington	Public School	016F	CLASSROOM FAUCET RM 124
LCCA	Brockton	00440055	Brockton: Huntington	Public School	016F	CLASSROOM FAUCET RM 124
LCCA	Brockton	00440055	Brockton: Huntington	Public School	016P	CLASSROOM FAUCET RM 124
LCCA	Brockton	00440055	Brockton: Huntington	Public School	016P	CLASSROOM FAUCET RM 124
LCCA	Brockton	00440055	Brockton: Huntington	Public School	018F	CLASSROOM FAUCET RM 101 & 102
LCCA	Brockton	00440055	Brockton: Huntington	Public School	018F	CLASSROOM FAUCET RM 101 & 102
LCCA	Brockton	00440055	Brockton: Huntington	Public School	018P	CLASSROOM FAUCET RM 101 & 102
LCCA	Brockton	00440055	Brockton: Huntington	Public School	018P	CLASSROOM FAUCET RM 101 & 102
LCCA	Brockton	00440055	Brockton: Huntington	Public School	020F	CLASSROOM FAUCET RM 212
LCCA	Brockton	00440055	Brockton: Huntington	Public School	020F	CLASSROOM FAUCET RM 212
LCCA	Brockton	00440055	Brockton: Huntington	Public School	020P	CLASSROOM FAUCET RM 212
LCCA	Brockton	00440055	Brockton: Huntington	Public School	020P	CLASSROOM FAUCET RM 212
LCCA	Brockton	00440055	Brockton: Huntington	Public School	022F	CLASSROOM FAUCET RM 209 & 210
LCCA	Brockton	00440055	Brockton: Huntington	Public School	022F	CLASSROOM FAUCET RM 209 & 210

LCCA	Brockton	00440055	Brockton: Huntington	Public School	022P	CLASSROOM FAUCET RM 209 & 210
LCCA	Brockton	00440055	Brockton: Huntington	Public School	022P	CLASSROOM FAUCET RM 209 & 210
LCCA	Brockton	00440055	Brockton: Huntington	Public School	023P	BUBBLER RM 209 & 210
LCCA	Brockton	00440055	Brockton: Huntington	Public School	023P	BUBBLER RM 209 & 210
LCCA	Brockton	00440055	Brockton: Huntington	Public School	024F	CLASSROOM FAUCET RM 208
LCCA	Brockton	00440055	Brockton: Huntington	Public School	024F	CLASSROOM FAUCET RM 208
LCCA	Brockton	00440055	Brockton: Huntington	Public School	024P	CLASSROOM FAUCET RM 208
LCCA	Brockton	00440055	Brockton: Huntington	Public School	024P	CLASSROOM FAUCET RM 208
LCCA	Brockton	00440055	Brockton: Huntington	Public School	025F	CLASSROOM FAUCET LIBRARY
LCCA	Brockton	00440055	Brockton: Huntington	Public School	025F	CLASSROOM FAUCET LIBRARY
LCCA	Brockton	00440055	Brockton: Huntington	Public School	025P	CLASSROOM FAUCET LIBRARY
LCCA	Brockton	00440055	Brockton: Huntington	Public School	025P	CLASSROOM FAUCET LIBRARY
LCCA	Brockton	00440055	Brockton: Huntington	Public School	028P	BUBBLER RM 214 & 215
LCCA	Brockton	00440055	Brockton: Huntington	Public School	028P	BUBBLER RM 214 & 215
LCCA	Brockton	00440055	Brockton: Huntington	Public School	029F	CLASSROOM FAUCET RM 214 & 215
LCCA	Brockton	00440055	Brockton: Huntington	Public School	029F	CLASSROOM FAUCET RM 214 & 215
LCCA	Brockton	00440055	Brockton: Huntington	Public School	029P	CLASSROOM FAUCET RM 214 & 215
LCCA	Brockton	00440055	Brockton: Huntington	Public School	029P	CLASSROOM FAUCET RM 214 & 215
LCCA	Brockton	00440055	Brockton: Huntington	Public School	030F	CLASSROOM FAUCET RM 216 & 217
LCCA	Brockton	00440055	Brockton: Huntington	Public School	030F	CLASSROOM FAUCET RM 216 & 217

LCCA	Brockton	00440055	Brockton: Huntington	Public School	030P	CLASSROOM FAUCET RM 216 & 217
LCCA	Brockton	00440055	Brockton: Huntington	Public School	030P	CLASSROOM FAUCET RM 216 & 217
LCCA	Brockton	00440055	Brockton: Huntington	Public School	031P	BUBBLER RM 216 & 217
LCCA	Brockton	00440055	Brockton: Huntington	Public School	031P	BUBBLER RM 216 & 217
LCCA	Brockton	00440055	Brockton: Huntington	Public School	032P	BUBBLER RM 201 & 202
LCCA	Brockton	00440055	Brockton: Huntington	Public School	032P	BUBBLER RM 201 & 202
LCCA	Brockton	00440055	Brockton: Huntington	Public School	033F	CLASSROOM FAUCET RM 201 & 202
LCCA	Brockton	00440055	Brockton: Huntington	Public School	033F	CLASSROOM FAUCET RM 201 & 202
LCCA	Brockton	00440055	Brockton: Huntington	Public School	033P	CLASSROOM FAUCET RM 201 & 202
LCCA	Brockton	00440055	Brockton: Huntington	Public School	033P	CLASSROOM FAUCET RM 201 & 202
LCCA	Brockton	00440055	Brockton: Huntington	Public School	034F	CLASSROOM FAUCET RM B25
LCCA	Brockton	00440055	Brockton: Huntington	Public School	034F	CLASSROOM FAUCET RM B25
LCCA	Brockton	00440055	Brockton: Huntington	Public School	034P	CLASSROOM FAUCET RM B25
LCCA	Brockton	00440055	Brockton: Huntington	Public School	034P	CLASSROOM FAUCET RM B25
LCCA	Brockton	00440055	Brockton: Huntington	Public School	035F	CLASSROOM FAUCET RM B24
LCCA	Brockton	00440055	Brockton: Huntington	Public School	035F	CLASSROOM FAUCET RM B24
LCCA	Brockton	00440055	Brockton: Huntington	Public School	035P	CLASSROOM FAUCET RM B24
LCCA	Brockton	00440055	Brockton: Huntington	Public School	035P	CLASSROOM FAUCET RM B24

l. The action level for copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not de

WELL IDENTIFICATION	ANALYTE NAME	RESULT	UNITS OF MEASURE	METHOD DETECTION LIMIT	ANALYTICAL METHOD	ANALYSIS DATE	LAB SAMPLE ID
	LEAD	0.0026	MG/L	0.0010	EPA 200.8	RI	1612-28533-001
	COPPER	0.076	MG/L	0.0010	EPA 200.8	RI	1612-28533-001
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI	1612-28533-003
	COPPER	0.050	MG/L	0.0010	EPA 200.8	RI	1612-28533-003
	LEAD	0.010	MG/L	0.0010	EPA 200.8	RI	1612-28533-002
	COPPER	0.093	MG/L	0.0010	EPA 200.8	RI	1612-28533-002
	LEAD	0.0020	MG/L	0.0010	EPA 200.8	RI	1612-28533-004
	COPPER	0.093	MG/L	0.0010	EPA 200.8	RI	1612-28533-004
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI	1612-28533-006
	COPPER	0.11	MG/L	0.0010	EPA 200.8	RI	1612-28533-006
	LEAD	0.0021	MG/L	0.0010	EPA 200.8	RI	1612-28533-005
	COPPER	0.12	MG/L	0.0010	EPA 200.8	RI	1612-28533-005
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI	1612-28533-008
	COPPER	0.066	MG/L	0.0010	EPA 200.8	RI	1612-28533-008
	LEAD	0.0046	MG/L	0.0010	EPA 200.8	RI	1612-28533-007
	COPPER	0.081	MG/L	0.0010	EPA 200.8	RI	1612-28533-007
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI	1612-28533-010
	COPPER	0.077	MG/L	0.0010	EPA 200.8	RI	1612-28533-010

	LEAD	0.0015	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-009
	COPPER	0.076	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-009
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-011
	COPPER	0.092	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-011
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-013
	COPPER	0.048	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-013
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-012
	COPPER	0.074	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-012
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-015
	COPPER	0.080	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-015
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-014
	COPPER	0.090	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-014
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-017
	COPPER	0.029	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-017
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-016
	COPPER	0.042	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-016
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-019
	COPPER	0.072	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-019
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-018
	COPPER	0.074	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-018

	LEAD	0.0019	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-020
	COPPER	0.070	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-020
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-022
	COPPER	0.077	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-022
	LEAD	0.0011	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-021
	COPPER	0.093	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-021
	LEAD	0.0021	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-024
	COPPER	0.64	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-024
	LEAD	0.0020	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-023
	COPPER	0.081	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-023
	LEAD	0.0027	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-026
	COPPER	0.20	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-026
	LEAD	0.0015	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-025
	COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-025
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-028
	COPPER	0.044	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-028
	LEAD	0.0023	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-027
	COPPER	0.076	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-027
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-030
	COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-030

	LEAD	0.0039	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-029
	COPPER	0.18	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-029
	LEAD	0.0019	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-031
	COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-031
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-033
	COPPER	0.076	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-033
	LEAD	0.0012	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-032
	COPPER	0.098	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-032
	LEAD	0.0019	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-035
	COPPER	0.055	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-035
	LEAD	0.017	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-034
	COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-034
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-036
	COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-036
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-038
	COPPER	0.085	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-038
	LEAD	0.0021	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-037
	COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-037
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-040
	COPPER	0.096	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-040

	LEAD	0.0026	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-039
	COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-039
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-041
	COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-041
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-042
	COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-042
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-044
	COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-044
	LEAD	0.0036	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-043
	COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-043
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-046
	COPPER	0.083	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-046
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-045
	COPPER	0.092	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-045
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-048
	COPPER	0.083	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-048
	LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-047
	COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28533-047

ected above the MDL.

ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	TIME COLLECTION	REPORT DATE
	J DILLON/J WILLETT	11/19/2016	11:19:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:19:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:20:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:20:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:19:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:19:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:25:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:25:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:26:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:26:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:25:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:25:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:29:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:29:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:28:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:28:00	24-Jan-17
	J WILLETT	11/22/2016	05:48:00	24-Jan-17
	J WILLETT	11/22/2016	05:48:00	24-Jan-17

	J WILLETT	11/22/2016	05:46:00	24-Jan-17
	J WILLETT	11/22/2016	05:46:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:32:00	24-Jan-17
	J DILLON/J WILLETT	11/19/2016	11:32:00	24-Jan-17
	JIM DILLON	11/19/2016	11:33:00	24-Jan-17
	JIM DILLON	11/19/2016	11:33:00	24-Jan-17
	JIM DILLON	11/19/2016	11:32:00	24-Jan-17
	JIM DILLON	11/19/2016	11:32:00	24-Jan-17
	JIM DILLON	11/19/2016	11:34:00	24-Jan-17
	JIM DILLON	11/19/2016	11:34:00	24-Jan-17
	JIM DILLON	11/19/2016	11:34:00	24-Jan-17
	JIM DILLON	11/19/2016	11:34:00	24-Jan-17
	JIM DILLON	11/19/2016	11:34:00	24-Jan-17
	JIM DILLON	11/19/2016	11:16:00	24-Jan-17
	JIM DILLON	11/19/2016	11:16:00	24-Jan-17
	JIM DILLON	11/19/2016	11:16:00	24-Jan-17
	JIM DILLON	11/19/2016	11:16:00	24-Jan-17
	JIM DILLON	11/19/2016	11:50:00	24-Jan-17
	JIM DILLON	11/19/2016	11:50:00	24-Jan-17
	JIM DILLON	11/19/2016	11:50:00	24-Jan-17
	JIM DILLON	11/19/2016	11:50:00	24-Jan-17

	JIM DILLON	11/19/2016	11:49:00	24-Jan-17
	JIM DILLON	11/19/2016	11:49:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:52:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:52:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:52:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:52:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:56:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:56:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:54:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:54:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	12:01:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	12:01:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:59:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:59:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:42:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:42:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:41:00	24-Jan-17
	J DILLION/J HASOMERIS	11/19/2016	11:41:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:26:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:26:00	24-Jan-17

	J HOSEMERIS	11/19/2016	11:25:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:25:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:25:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:25:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:29:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:29:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:28:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:28:00	24-Jan-17
	J WILLETT	11/22/2016	05:33:00	24-Jan-17
	J WILLETT	11/22/2016	05:33:00	24-Jan-17
	J WILLETT	11/22/2016	05:11:00	24-Jan-17
	J WILLETT	11/22/2016	05:11:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:19:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:19:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:20:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:20:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:19:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:19:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:16:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:16:00	24-Jan-17

	J HOSEMERIS	11/19/2016	11:15:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:15:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:15:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:15:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:34:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:34:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:35:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:35:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:34:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:34:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:51:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:51:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:50:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:50:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:54:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:54:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:53:00	24-Jan-17
	J HOSEMERIS	11/19/2016	11:53:00	24-Jan-17

