

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any result greater than 0.015 mg/l.

PORTTYPECO	CITYTOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	PLECOMM	ANALYTENAME	RESULT
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	001P	KITCHEN		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	001P	KITCHEN		COPPER	0.13
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	002F	KITCHEN		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	002F	KITCHEN		COPPER	0.088
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	002P	KITCHEN		LEAD	0.0023
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	002P	KITCHEN		COPPER	0.16
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	003F	KITCHEN PREP SINK		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	003F	KITCHEN PREP SINK		COPPER	0.050
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	003P	KITCHEN PREP SINK		LEAD	0.0020
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	003P	KITCHEN PREP SINK		COPPER	0.25
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	004F	KITCHEN PREP SINK		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	004F	KITCHEN PREP SINK		COPPER	0.074
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	004P	KITCHEN PREP SINK		LEAD	0.0053
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	004P	KITCHEN PREP SINK		COPPER	0.18
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	005P	RM 109		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	005P	RM 109		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	006F	RM 109		LEAD	0.0012
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	006F	RM 109		COPPER	0.072
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	006P	RM 109		LEAD	0.0044
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	006P	RM 109		COPPER	0.092
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	007P	RM 108		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	007P	RM 108		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	008F	RM 108		LEAD	ND

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	008F	RM 108		COPPER	0.049
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	008P	RM 108		LEAD	0.0097
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	008P	RM 108		COPPER	0.14
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	009P	RM 107		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	009P	RM 107		COPPER	0.12
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	010F	RM 107		LEAD	0.0011
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	010F	RM 107		COPPER	0.14
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	010P	RM 107		LEAD	0.0036
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	010P	RM 107		COPPER	0.32
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	012P	HALLWAY BOTTLE FILLER OUTSIDE		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	012P	HALLWAY BOTTLE FILLER OUTSIDE		COPPER	0.73
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	013F	HALLWAY OUTSIDE RM 107		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	013F	HALLWAY OUTSIDE RM 107		COPPER	0.31
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	013P	HALLWAY OUTSIDE RM 107		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	013P	HALLWAY OUTSIDE RM 107		COPPER	0.86
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	014P	RM 106		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	014P	RM 106		COPPER	0.099
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	015F	RM 106		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	015F	RM 106		COPPER	0.10
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	015P	RM 106		LEAD	0.0048
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	015P	RM 106		COPPER	0.17
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	016P	RM 105		LEAD	0.0013
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	016P	RM 105		COPPER	0.16
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	017F	RM 105		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	017F	RM 105		COPPER	0.098

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	017P	RM 105		LEAD	0.0089
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	017P	RM 105		COPPER	0.12
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	018F	HALLWAY OUTSIDE RM 105		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	018F	HALLWAY OUTSIDE RM 105		COPPER	0.054
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	018P	HALLWAY OUTSIDE RM 105		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	018P	HALLWAY OUTSIDE RM 105		COPPER	0.55
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	019P	HALLWAY OUTSIDE RM 105		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	019P	HALLWAY OUTSIDE RM 105		COPPER	0.078
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	021F	RM 104		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	021F	RM 104		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	021P	RM 104		LEAD	0.0070
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	021P	RM 104		COPPER	0.14
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	023F	RM 103		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	023F	RM 103		COPPER	0.15
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	023P	RM 103		LEAD	0.0043
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	023P	RM 103		COPPER	0.17
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	024P	RM 102		LEAD	0.0018
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	024P	RM 102		COPPER	0.14
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	025F	RM 102		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	025F	RM 102		COPPER	0.099
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	025P	RM 102		LEAD	0.0078
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	025P	RM 102		COPPER	0.23
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	026P	OUTSIDE RM 144		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	026P	OUTSIDE RM 144		COPPER	0.15
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	027F	OUTSIDE RM 144		LEAD	ND

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	027F	OUTSIDE RM 144		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	027P	OUTSIDE RM 144		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	027P	OUTSIDE RM 144		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	028F	OUTSIDE RM 144		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	028F	OUTSIDE RM 144		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	028P	OUTSIDE RM 144		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	028P	OUTSIDE RM 144		COPPER	0.16
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	030F	TEACHERS LOUNGE		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	030F	TEACHERS LOUNGE		COPPER	0.047
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	030P	TEACHERS LOUNGE		LEAD	0.0021
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	030P	TEACHERS LOUNGE		COPPER	0.090
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	031F	TEACHERS WORK RM		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	031F	TEACHERS WORK RM		COPPER	0.050
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	031P	TEACHERS WORK RM		LEAD	0.0031
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	031P	TEACHERS WORK RM		COPPER	0.081
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	032F	RM 161		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	032F	RM 161		COPPER	0.040
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	032P	RM 161		LEAD	0.026
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	032P	RM 161		COPPER	0.25
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	034F	RM 136		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	034F	RM 136		COPPER	0.030
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	034P	RM 136		LEAD	0.020
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	034P	RM 136		COPPER	0.78
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	035P	RM 141		LEAD	0.0014
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	035P	RM 141		COPPER	0.10

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	036F	RM 141		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	036F	RM 141		COPPER	0.082
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	036P	RM 141		LEAD	0.0061
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	036P	RM 141		COPPER	0.10
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	038F	RM 219 FAUCET		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	038F	RM 219 FAUCET		COPPER	0.015
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	038P	RM 219 FAUCET		LEAD	0.0058
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	038P	RM 219 FAUCET		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	039F	RM 218		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	039F	RM 218		COPPER	0.40
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	039P	RM 218		LEAD	0.0020
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	039P	RM 218		COPPER	0.32
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	040F	RM 218		LEAD	0.0022
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	040F	RM 218		COPPER	1.1
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	040P	RM 218		LEAD	0.059
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	040P	RM 218		COPPER	49.2
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	041P	RM 215		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	041P	RM 215		COPPER	0.086
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	042F	RM 215		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	042F	RM 215		COPPER	0.035
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	042P	RM 215		LEAD	0.012
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	042P	RM 215		COPPER	0.14
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	043P	RM 214		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	043P	RM 214		COPPER	0.100
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	044F	RM 214		LEAD	ND

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	044F	RM 214		COPPER	0.030
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	044P	RM 214		LEAD	0.0070
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	044P	RM 214		COPPER	0.090
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	045P	RM 213		LEAD	0.0020
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	045P	RM 213		COPPER	0.081
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	046F	RM 213		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	046F	RM 213		COPPER	0.039
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	046P	RM 213		LEAD	0.011
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	046P	RM 213		COPPER	0.086
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	047P	RM 212		LEAD	0.0038
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	047P	RM 212		COPPER	0.093
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	048F	RM 212		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	048F	RM 212		COPPER	0.049
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	048P	RM 212		LEAD	0.0065
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	048P	RM 212		COPPER	0.084
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	049P	RM 211		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	049P	RM 211		COPPER	0.094
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	050F	RM 211		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	050F	RM 211		COPPER	0.063
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	050P	RM 211		LEAD	0.0059
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	050P	RM 211		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	051P	RM 209		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	051P	RM 209		COPPER	0.082
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	052F	RM 209		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	052F	RM 209		COPPER	0.061

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	052P	RM 209		LEAD	0.0029
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	052P	RM 209		COPPER	0.068
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	054F	RM 282		LEAD	0.0021
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	054F	RM 282		COPPER	0.19
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	054P	RM 282		LEAD	0.022
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	054P	RM 282		COPPER	0.40
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	055P	RM 281		LEAD	0.0071
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	055P	RM 281		COPPER	1.6
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	056F	RM 281		LEAD	0.0020
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	056F	RM 281		COPPER	0.094
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	056P	RM 281		LEAD	0.065
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	056P	RM 281		COPPER	2.0
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	057P	RM 208B		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	057P	RM 208B		COPPER	0.086
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	058F	RM 208B		LEAD	0.0042
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	058F	RM 208B		COPPER	0.082
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	058P	RM 208B		LEAD	0.012
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	058P	RM 208B		COPPER	0.079
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	059P	RM 208A		LEAD	0.0013
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	059P	RM 208A		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	060F	RM 208A		LEAD	0.0043
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	060F	RM 208A		COPPER	0.070
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	060P	RM 208A		LEAD	0.046
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	060P	RM 208A		COPPER	0.68

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	061P	HALLWAY OUTSIDE RM 266		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	061P	HALLWAY OUTSIDE RM 266		COPPER	0.019
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	062F	HALLWAY OUTSIDE RM 266		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	062F	HALLWAY OUTSIDE RM 266		COPPER	0.0074
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	062P	HALLWAY OUTSIDE RM 266		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	062P	HALLWAY OUTSIDE RM 266		COPPER	0.021
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	063P	HALLWAY OUTSIDE RM 266		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	063P	HALLWAY OUTSIDE RM 266		COPPER	0.023
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	064F	HALLWAY OUTSIDE RM 266		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	064F	HALLWAY OUTSIDE RM 266		COPPER	0.011
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	064P	HALLWAY OUTSIDE RM 266		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	064P	HALLWAY OUTSIDE RM 266		COPPER	0.023
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	065F	NURSES OFFICE		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	065F	NURSES OFFICE		COPPER	0.095
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	065P	NURSES OFFICE		LEAD	0.0014
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	065P	NURSES OFFICE		COPPER	0.12
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	066F	NURSES BATHROOM		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	066F	NURSES BATHROOM		COPPER	0.26
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	066P	NURSES BATHROOM		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	066P	NURSES BATHROOM		COPPER	0.12
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	067F	NURSES BATHROOM BACK		LEAD	ND

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	067F	NURSES BATHROOM BACK		COPPER	0.14
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	067P	NURSES BATHROOM BACK		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	067P	NURSES BATHROOM BACK		COPPER	0.13
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	068P	RM 223		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	068P	RM 223		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	069F	RM 223		LEAD	0.0016
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	069F	RM 223		COPPER	0.098
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	069P	RM 223		LEAD	0.0058
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	069P	RM 223		COPPER	0.24
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	070F	RM 224		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	070F	RM 224		COPPER	0.014
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	070P	RM 224		LEAD	0.0059
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	070P	RM 224		COPPER	0.087
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	071F	RM 232		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	071F	RM 232		COPPER	0.012
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	071P	RM 232		LEAD	0.0062
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	071P	RM 232		COPPER	0.092
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	072F	RM 233		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	072F	RM 233		COPPER	0.024

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	072P	RM 233		LEAD	0.0042
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	072P	RM 233		COPPER	0.088
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	073F	RM 241		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	073F	RM 241		COPPER	0.030
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	073P	RM 241		LEAD	0.0020
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	073P	RM 241		COPPER	0.10
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	074P	RM 279		LEAD	0.011

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	074P	RM 279		COPPER	0.66
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	075F	RM 279		LEAD	0.0021
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	075F	RM 279		COPPER	0.093
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	075P	RM 279		LEAD	0.038
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	075P	RM 279		COPPER	1.2
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	076F	RM 242		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	076F	RM 242		COPPER	0.033

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	076P	RM 242		LEAD	0.0070
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	076P	RM 242		COPPER	0.089
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	078F	RM 278		LEAD	0.0025
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	078F	RM 278		COPPER	0.15
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	078P	RM 278		LEAD	0.011
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	078P	RM 278		COPPER	0.27
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	079F	RM 249		LEAD	ND

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	079F	RM 249		COPPER	0.042
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	079P	RM 249		LEAD	0.0053
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	079P	RM 249		COPPER	0.089
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	080F	RM 251		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	080F	RM 251		COPPER	0.078
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	080P	RM 251		LEAD	0.0040
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	080P	RM 251		COPPER	0.087

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	082F	RM 319 LIBRARY		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	082F	RM 319 LIBRARY		COPPER	0.069
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	082P	RM 319 LIBRARY		LEAD	0.0051
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	082P	RM 319 LIBRARY		COPPER	0.39
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	083P	RM 309 BUB		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	083P	RM 309 BUB		COPPER	0.10
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	084F	RM 309 FAUC		LEAD	ND

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	084F	RM 309 FAUC		COPPER	0.034
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	084P	RM 309 FAUC		LEAD	0.016
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	084P	RM 309 FAUC		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	085P	RM 308 BUB		LEAD	0.0014
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	085P	RM 308 BUB		COPPER	0.094
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	086F	RM 308 FAUC		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	086F	RM 308 FAUC		COPPER	0.029

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	086P	RM 308 FAUC		LEAD	0.0090
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	086P	RM 308 FAUC		COPPER	0.098
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	087P	RM 307 BUB		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	087P	RM 307 BUB		COPPER	0.100
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	088F	RM 307 FAUC		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	088F	RM 307 FAUC		COPPER	0.034
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	088P	RM 307 FAUC		LEAD	0.0074

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	088P	RM 307 FAUC		COPPER	0.083
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	089P	RM 306 BUB		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	089P	RM 306 BUB		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	090F	RM 306 FAU		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	090F	RM 306 FAU		COPPER	0.041
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	090P	RM 306 FAU		LEAD	0.0046
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	090P	RM 306 FAU		COPPER	0.11

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	091P	RM 305 BUB		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	091P	RM 305 BUB		COPPER	0.13
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	092F	RM 305 FAUC		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	092F	RM 305 FAUC		COPPER	0.043
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	092P	RM 305 FAUC		LEAD	0.0058
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	092P	RM 305 FAUC		COPPER	0.15
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	093P	RM 304		LEAD	ND

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	093P	RM 304		COPPER	0.076
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	094F	RM 304		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	094F	RM 304		COPPER	0.045
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	094P	RM 304		LEAD	0.0081
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	094P	RM 304		COPPER	0.15
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	095F	RM 348		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	095F	RM 348		COPPER	0.063

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	095P	RM 348		LEAD	0.0014
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	095P	RM 348		COPPER	0.34
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	096F	RM 303 BUB		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	096F	RM 303 BUB		COPPER	0.064
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	096P	RM 303 BUB		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	096P	RM 303 BUB		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	097F	RM 303		LEAD	0.014

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	097F	RM 303		COPPER	0.16
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	097P	RM 303 FAUCET		LEAD	0.0043
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	097P	RM 303 FAUCET		COPPER	0.12
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	098F	RM 302 FAUCET		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	098F	RM 302 FAUCET		COPPER	0.052
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	098P	RM 302 FAUCET		LEAD	0.0085
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	098P	RM 302 FAUCET		COPPER	0.34

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	099P	RM 302		LEAD	0.0024
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	099P	RM 302		COPPER	0.22
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	100P	BUB HALLWAY OUTSIDE RM 336		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	100P	BUB HALLWAY OUTSIDE RM 336		COPPER	0.44
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	101F	W FILL HALLWAY OUTSIDE RM 336		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	101F	W FILL HALLWAY OUTSIDE RM 336		COPPER	0.32
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	101P	W FILL HALLWAY OUTSIDE RM 336		LEAD	ND

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	101P	W FILL HALLWAY OUTSIDE RM 336		COPPER	0.65
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	102P	BUB HALLWAY OUTSIDE RM 336		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	102P	BUB HALLWAY OUTSIDE RM 336		COPPER	0.68
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	103F	HALLWAY OUTSIDE RM 336		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	103F	HALLWAY OUTSIDE RM 336		COPPER	0.29
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	103P	FILL HALLWAY OUTSIDE RM 336		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	103P	FILL HALLWAY OUTSIDE RM 336		COPPER	0.74

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	104F	RM 336 ART RM NEAR DOOR		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	104F	RM 336 ART RM NEAR DOOR		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	104P	RM 336 ART RM NEAR DOOR		LEAD	0.0047
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	104P	RM 336 ART RM NEAR DOOR		COPPER	0.11
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	105F	RM 336 ART RM		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	105F	RM 336 ART RM		COPPER	0.093
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	105P	RM 336 ART RM		LEAD	0.0026

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	105P	RM 336 ART RM		COPPER	0.076
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	106P	RM 323		LEAD	0.100
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	106P	RM 323		COPPER	4.1
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	107F	RM 323		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	107F	RM 323		COPPER	0.024
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	107P	RM 323		LEAD	0.014
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	107P	RM 323		COPPER	0.91

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	108P	RM 324		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	108P	RM 324		COPPER	0.51
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	109F	RM 324		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	109F	RM 324		COPPER	0.031
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	109P	RM 324		LEAD	0.014
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	109P	RM 324		COPPER	0.18
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	110P	RM 325		LEAD	0.0010

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	110P	RM 325		COPPER	0.18
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	111F	RM 325		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	111F	RM 325		COPPER	0.020
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	111P	RM 325		LEAD	0.0031
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	111P	RM 325		COPPER	0.14
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	112F	RM 326		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	112F	RM 326		COPPER	0.019

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	112P	RM 326		LEAD	0.0055
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	112P	RM 326		COPPER	0.13
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	113P	RM 326		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	113P	RM 326		COPPER	0.12
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	114F	RM 327		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	114F	RM 327		COPPER	0.036
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	114P	RM 327		LEAD	0.0039

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	114P	RM 327		COPPER	0.37
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	115P	RM 327		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	115P	RM 327		COPPER	0.17
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	116F	RM 328		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	116F	RM 328		COPPER	0.036
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	116P	RM 328		LEAD	0.0033
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	116P	RM 328		COPPER	0.11

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	117P	RM 328		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	117P	RM 328		COPPER	0.12
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	118F	RM 349		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	118F	RM 349		COPPER	0.10
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	118P	RM 349		LEAD	0.0057
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	118P	RM 349		COPPER	0.60
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	119F	RM 329		LEAD	ND

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	119F	RM 329		COPPER	0.047
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	119P	RM 329		LEAD	0.0085
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	119P	RM 329		COPPER	0.18
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	120P	RM 329		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	120P	RM 329		COPPER	0.18
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	121F	RM 331		LEAD	ND
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	121F	RM 331		COPPER	0.10

LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	121P	RM 331		LEAD	0.070
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	121P	RM 331		COPPER	0.49
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	122P	RM 331		LEAD	0.0013
LCCA	Brockton	00440065	Brockton: Louis F Angelo Elementary	Public School	122P	RM 331		COPPER	0.16

ater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

UNIT OF MEASURE	MDL DETECTION	ANALYTICAL METHOD	ANALYSIS LEVEL	LAB SAMPLE ID	ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	TIME COLLECTION	REPORT DATE
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-001		ANDREW DURHAM	11/19/2016	06:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-001		ANDREW DURHAM	11/19/2016	06:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-003		ANDREW DURHAM	11/19/2016	06:28:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-003		ANDREW DURHAM	11/19/2016	06:28:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-002		ANDREW DURHAM	11/19/2016	06:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-002		ANDREW DURHAM	11/19/2016	06:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-005		ANDREW DURHAM	11/19/2016	06:30:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-005		ANDREW DURHAM	11/19/2016	06:30:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-004		ANDREW DURHAM	11/19/2016	06:29:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-004		ANDREW DURHAM	11/19/2016	06:29:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-007		ANDREW DURHAM	11/19/2016	06:32:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-007		ANDREW DURHAM	11/19/2016	06:32:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-006		ANDREW DURHAM	11/19/2016	06:31:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-006		ANDREW DURHAM	11/19/2016	06:31:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-008		ANDREW DURHAM	11/19/2016	06:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-008		ANDREW DURHAM	11/19/2016	06:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-010		ANDREW DURHAM	11/19/2016	06:35:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-010		ANDREW DURHAM	11/19/2016	06:35:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-009		ANDREW DURHAM	11/19/2016	06:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-009		ANDREW DURHAM	11/19/2016	06:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-011		ANDREW DURHAM	11/19/2016	06:36:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-011		ANDREW DURHAM	11/19/2016	06:36:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-013		ANDREW DURHAM	11/19/2016	06:37:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-051		ANDREW DURHAM	11/19/2016	07:04:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-051		ANDREW DURHAM	11/19/2016	07:04:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-050		ANDREW DURHAM	11/19/2016	07:03:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-050		ANDREW DURHAM	11/19/2016	07:03:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-053		ANDREW DURHAM	11/19/2016	08:03:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-053		ANDREW DURHAM	11/19/2016	08:03:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-052		ANDREW DURHAM	11/19/2016	08:02:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-052		ANDREW DURHAM	11/19/2016	08:02:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-184		JIM WILLETT	11/22/2016	09:21:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-184		JIM WILLETT	11/22/2016	09:21:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-183		JIM WILLETT	11/22/2016	09:20:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-183		JIM WILLETT	11/22/2016	09:20:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-055		ANDREW DURHAM	11/19/2016	07:19:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-055		ANDREW DURHAM	11/19/2016	07:19:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-054		ANDREW DURHAM	11/19/2016	07:18:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-054		ANDREW DURHAM	11/19/2016	07:18:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-056		ANDREW DURHAM	11/19/2016	07:13:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-056		ANDREW DURHAM	11/19/2016	07:13:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-058		ANDREW DURHAM	11/19/2016	07:14:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-058		ANDREW DURHAM	11/19/2016	07:14:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-057		ANDREW DURHAM	11/19/2016	07:13:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-057		ANDREW DURHAM	11/19/2016	07:13:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-059		ANDREW DURHAM	11/19/2016	07:15:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-059		ANDREW DURHAM	11/19/2016	07:15:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-061		ANDREW DURHAM	11/19/2016	07:16:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-072		ANDREW DURHAM	11/19/2016	07:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-072		ANDREW DURHAM	11/19/2016	07:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-075		ANDREW DURHAM	11/19/2016	07:31:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-075		ANDREW DURHAM	11/19/2016	07:31:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-074		ANDREW DURHAM	11/19/2016	07:30:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-074		ANDREW DURHAM	11/19/2016	07:30:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-076		ANDREW DURHAM	11/19/2016	07:31:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-076		ANDREW DURHAM	11/19/2016	07:31:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-078		ANDREW DURHAM	11/19/2016	07:32:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-078		ANDREW DURHAM	11/19/2016	07:32:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-077		ANDREW DURHAM	11/19/2016	07:31:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-077		ANDREW DURHAM	11/19/2016	07:31:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-079		ANDREW DURHAM	11/19/2016	07:33:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-079		ANDREW DURHAM	11/19/2016	07:33:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-081		ANDREW DURHAM	11/19/2016	07:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-081		ANDREW DURHAM	11/19/2016	07:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-080		ANDREW DURHAM	11/19/2016	07:33:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-080		ANDREW DURHAM	11/19/2016	07:33:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-082		ANDREW DURHAM	11/19/2016	07:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28843-082		ANDREW DURHAM	11/19/2016	07:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYT ICAL	1612-28843-084		ANDREW DURHAM	11/19/2016	07:35:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYT ICAL	1612-28843-084		ANDREW DURHAM	11/19/2016	07:35:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYT ICAL	1612-28843-083		ANDREW DURHAM	11/19/2016	07:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYT ICAL	1612-28843-083		ANDREW DURHAM	11/19/2016	07:34:00	28-Jan-17

MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-085		ANDREW DURHAM	11/19/2016	07:37:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-085		ANDREW DURHAM	11/19/2016	07:37:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-087		ANDREW DURHAM	11/19/2016	07:38:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-087		ANDREW DURHAM	11/19/2016	07:38:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-086		ANDREW DURHAM	11/19/2016	07:37:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-086		ANDREW DURHAM	11/19/2016	07:37:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-088		ANDREW DURHAM	11/19/2016	07:39:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-088		ANDREW DURHAM	11/19/2016	07:39:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-090		ANDREW DURHAM	11/19/2016	07:40:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-090		ANDREW DURHAM	11/19/2016	07:40:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-089		ANDREW DURHAM	11/19/2016	07:39:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-089		ANDREW DURHAM	11/19/2016	07:39:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-092		ANDREW DURHAM	11/19/2016	07:42:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-092		ANDREW DURHAM	11/19/2016	07:42:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-091		ANDREW DURHAM	11/19/2016	07:41:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-091		ANDREW DURHAM	11/19/2016	07:41:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-094		ANDREW DURHAM	11/19/2016	07:44:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-094		ANDREW DURHAM	11/19/2016	07:44:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-093		ANDREW DURHAM	11/19/2016	07:43:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-093		ANDREW DURHAM	11/19/2016	07:43:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-096		ANDREW DURHAM	11/19/2016	07:45:00	28-Jan-17

MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-096		ANDREW DURHAM	11/19/2016	07:45:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-095		ANDREW DURHAM	11/19/2016	07:44:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-095		ANDREW DURHAM	11/19/2016	07:44:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-097		ANDREW DURHAM	11/19/2016	08:08:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-097		ANDREW DURHAM	11/19/2016	08:08:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-099		ANDREW DURHAM	11/19/2016	08:09:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-099		ANDREW DURHAM	11/19/2016	08:09:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-098		ANDREW DURHAM	11/19/2016	08:08:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-098		ANDREW DURHAM	11/19/2016	08:08:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-101		ANDREW DURHAM	11/19/2016	08:07:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-101		ANDREW DURHAM	11/19/2016	08:07:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-100		ANDREW DURHAM	11/19/2016	08:06:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-100		ANDREW DURHAM	11/19/2016	08:06:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-103		ANDREW DURHAM	11/19/2016	08:01:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-103		ANDREW DURHAM	11/19/2016	08:01:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-102		ANDREW DURHAM	11/19/2016	08:00:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-102		ANDREW DURHAM	11/19/2016	08:00:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-105		ANDREW DURHAM	11/19/2016	08:00:00	28-Jan-17
MG/L	0.0010	EPA 200.8	ANALYTICAL	1612-28843-105		ANDREW DURHAM	11/19/2016	08:00:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-104		ANDREW DURHAM	11/19/2016	07:59:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-104		ANDREW DURHAM	11/19/2016	07:59:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-107		ANDREW DURHAM	11/19/2016	07:58:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-107		ANDREW DURHAM	11/19/2016	07:58:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-106		ANDREW DURHAM	11/19/2016	07:57:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-106		ANDREW DURHAM	11/19/2016	07:57:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-108		ANDREW DURHAM	11/19/2016	07:52:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-108		ANDREW DURHAM	11/19/2016	07:52:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-110		ANDREW DURHAM	11/19/2016	07:53:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-110		ANDREW DURHAM	11/19/2016	07:53:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-109		ANDREW DURHAM	11/19/2016	07:52:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-109		ANDREW DURHAM	11/19/2016	07:52:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-112		ANDREW DURHAM	11/19/2016	07:56:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-112		ANDREW DURHAM	11/19/2016	07:56:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-111		ANDREW DURHAM	11/19/2016	07:55:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-111		ANDREW DURHAM	11/19/2016	07:55:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-114		ANDREW DURHAM	11/19/2016	07:51:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-114		ANDREW DURHAM	11/19/2016	07:51:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-113		ANDREW DURHAM	11/19/2016	07:50:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-113		ANDREW DURHAM	11/19/2016	07:50:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-116		ANDREW DURHAM	11/19/2016	07:48:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-116		ANDREW DURHAM	11/19/2016	07:48:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-115		ANDREW DURHAM	11/19/2016	07:47:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-115		ANDREW DURHAM	11/19/2016	07:47:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-118		ANDREW DURHAM	11/19/2016	07:46:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-118		ANDREW DURHAM	11/19/2016	07:46:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-117		ANDREW DURHAM	11/19/2016	07:45:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-117		ANDREW DURHAM	11/19/2016	07:45:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-120		ANDREW DURHAM	11/19/2016	08:59:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-120		ANDREW DURHAM	11/19/2016	08:59:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-119		ANDREW DURHAM	11/19/2016	08:58:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-119		ANDREW DURHAM	11/19/2016	08:58:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-121		ANDREW DURHAM	11/19/2016	08:14:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-121		ANDREW DURHAM	11/19/2016	08:14:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-123		ANDREW DURHAM	11/19/2016	08:15:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-123		ANDREW DURHAM	11/19/2016	08:15:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-122		ANDREW DURHAM	11/19/2016	08:14:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-122		ANDREW DURHAM	11/19/2016	08:14:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-124		ANDREW DURHAM	11/19/2016	08:16:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-124		ANDREW DURHAM	11/19/2016	08:16:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-126		ANDREW DURHAM	11/19/2016	08:17:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-126		ANDREW DURHAM	11/19/2016	08:17:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-125		ANDREW DURHAM	11/19/2016	08:16:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-125		ANDREW DURHAM	11/19/2016	08:16:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-127		ANDREW DURHAM	11/19/2016	08:18:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-127		ANDREW DURHAM	11/19/2016	08:18:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-129		ANDREW DURHAM	11/19/2016	08:19:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-129		ANDREW DURHAM	11/19/2016	08:19:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-128		ANDREW DURHAM	11/19/2016	08:18:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-128		ANDREW DURHAM	11/19/2016	08:18:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-130		ANDREW DURHAM	11/19/2016	08:20:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-130		ANDREW DURHAM	11/19/2016	08:20:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-132		ANDREW DURHAM	11/19/2016	08:21:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-132		ANDREW DURHAM	11/19/2016	08:21:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-131		ANDREW DURHAM	11/19/2016	08:20:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-131		ANDREW DURHAM	11/19/2016	08:20:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-133		ANDREW DURHAM	11/19/2016	08:21:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-133		ANDREW DURHAM	11/19/2016	08:21:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-135		ANDREW DURHAM	11/19/2016	08:22:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-135		ANDREW DURHAM	11/19/2016	08:22:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-134		ANDREW DURHAM	11/19/2016	08:21:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-134		ANDREW DURHAM	11/19/2016	08:21:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-136		ANDREW DURHAM	11/19/2016	08:24:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-136		ANDREW DURHAM	11/19/2016	08:24:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-138		ANDREW DURHAM	11/19/2016	08:24:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-138		ANDREW DURHAM	11/19/2016	08:24:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-137		ANDREW DURHAM	11/19/2016	08:23:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-137		ANDREW DURHAM	11/19/2016	08:23:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-140		ANDREW DURHAM	11/19/2016	08:29:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-140		ANDREW DURHAM	11/19/2016	08:29:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-139		ANDREW DURHAM	11/19/2016	08:28:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-139		ANDREW DURHAM	11/19/2016	08:28:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-142		ANDREW DURHAM	11/19/2016	08:28:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-142		ANDREW DURHAM	11/19/2016	08:28:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-141		ANDREW DURHAM	11/19/2016	08:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-141		ANDREW DURHAM	11/19/2016	08:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-185		ANDREW DURHAM	11/19/2016	08:27:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-185		ANDREW DURHAM	11/19/2016	08:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-143		ANDREW DURHAM	11/19/2016	08:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-143		ANDREW DURHAM	11/19/2016	08:27:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-145		ANDREW DURHAM	11/19/2016	08:31:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-145		ANDREW DURHAM	11/19/2016	08:31:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-144		ANDREW DURHAM	11/19/2016	08:30:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-144		ANDREW DURHAM	11/19/2016	08:30:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-146		ANDREW DURHAM	11/19/2016	08:30:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-146		ANDREW DURHAM	11/19/2016	08:30:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-147		ANDREW DURHAM	11/19/2016	08:35:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-147		ANDREW DURHAM	11/19/2016	08:35:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-149		ANDREW DURHAM	11/19/2016	08:36:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-149		ANDREW DURHAM	11/19/2016	08:36:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-148		ANDREW DURHAM	11/19/2016	08:35:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-148		ANDREW DURHAM	11/19/2016	08:35:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-150		ANDREW DURHAM	11/19/2016	08:37:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-150		ANDREW DURHAM	11/19/2016	08:37:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-152		ANDREW DURHAM	11/19/2016	08:38:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-152		ANDREW DURHAM	11/19/2016	08:38:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-151		ANDREW DURHAM	11/19/2016	08:37:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-151		ANDREW DURHAM	11/19/2016	08:37:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-154		ANDREW DURHAM	11/19/2016	08:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-154		ANDREW DURHAM	11/19/2016	08:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-153		ANDREW DURHAM	11/19/2016	08:33:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-153		ANDREW DURHAM	11/19/2016	08:33:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-156		ANDREW DURHAM	11/19/2016	08:35:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-156		ANDREW DURHAM	11/19/2016	08:35:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-155		ANDREW DURHAM	11/19/2016	08:34:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-155		ANDREW DURHAM	11/19/2016	08:34:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-157		ANDREW DURHAM	11/19/2016	08:52:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-157		ANDREW DURHAM	11/19/2016	08:52:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-159		ANDREW DURHAM	11/19/2016	08:53:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-159		ANDREW DURHAM	11/19/2016	08:53:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-158		ANDREW DURHAM	11/19/2016	08:52:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-158		ANDREW DURHAM	11/19/2016	08:52:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-160		ANDREW DURHAM	11/19/2016	08:54:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-160		ANDREW DURHAM	11/19/2016	08:54:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-162		ANDREW DURHAM	11/19/2016	08:55:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-162		ANDREW DURHAM	11/19/2016	08:55:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-161		ANDREW DURHAM	11/19/2016	08:54:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-161		ANDREW DURHAM	11/19/2016	08:54:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-163		ANDREW DURHAM	11/19/2016	08:57:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-163		ANDREW DURHAM	11/19/2016	08:57:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-165		ANDREW DURHAM	11/19/2016	08:58:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-165		ANDREW DURHAM	11/19/2016	08:58:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-164		ANDREW DURHAM	11/19/2016	08:58:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-164		ANDREW DURHAM	11/19/2016	08:58:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-167		ANDREW DURHAM	11/19/2016	08:51:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-167		ANDREW DURHAM	11/19/2016	08:51:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-166		ANDREW DURHAM	11/19/2016	08:50:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-166		ANDREW DURHAM	11/19/2016	08:50:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-168		ANDREW DURHAM	11/19/2016	08:50:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-168		ANDREW DURHAM	11/19/2016	08:50:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-170		ANDREW DURHAM	11/19/2016	08:48:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-170		ANDREW DURHAM	11/19/2016	08:48:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-169		ANDREW DURHAM	11/19/2016	08:47:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-169		ANDREW DURHAM	11/19/2016	08:47:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-171		ANDREW DURHAM	11/19/2016	08:47:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-171		ANDREW DURHAM	11/19/2016	08:47:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-173		ANDREW DURHAM	11/19/2016	08:46:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-173		ANDREW DURHAM	11/19/2016	08:46:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-172		ANDREW DURHAM	11/19/2016	08:45:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-172		ANDREW DURHAM	11/19/2016	08:45:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-174		ANDREW DURHAM	11/19/2016	08:45:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-174		ANDREW DURHAM	11/19/2016	08:45:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-176		ANDREW DURHAM	11/19/2016	08:45:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-176		ANDREW DURHAM	11/19/2016	08:45:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-175		ANDREW DURHAM	11/19/2016	08:44:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-175		ANDREW DURHAM	11/19/2016	08:44:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-178		ANDREW DURHAM	11/19/2016	08:43:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-178		ANDREW DURHAM	11/19/2016	08:43:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-177		ANDREW DURHAM	11/19/2016	08:42:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-177		ANDREW DURHAM	11/19/2016	08:42:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-179		ANDREW DURHAM	11/19/2016	08:42:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-179		ANDREW DURHAM	11/19/2016	08:42:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-181		ANDREW DURHAM	11/19/2016	08:40:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-181		ANDREW DURHAM	11/19/2016	08:40:00	28-Jan-17

MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-180		ANDREW DURHAM	11/19/2016	08:39:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-180		ANDREW DURHAM	11/19/2016	08:39:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-182		ANDREW DURHAM	11/19/2016	08:39:00	28-Jan-17
MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1612-28843-182		ANDREW DURHAM	11/19/2016	08:39:00	28-Jan-17