

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for c

PORTYPECO	CITYTOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	AMPLECOMMENT
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	001F	KITCHEN PREP SINK	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	001F	KITCHEN PREP SINK	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	001P	KITCHEN PREP SINK	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	001P	KITCHEN PREP SINK	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	002F	KITCHEN	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	002F	KITCHEN	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	002P	KITCHEN	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	002P	KITCHEN	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	003F	KITCHEN PREP SINK (ISLAND)	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	003F	KITCHEN PREP SINK (ISLAND)	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	003P	KITCHEN PREP SINK (ISLAND)	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	003P	KITCHEN PREP SINK (ISLAND)	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	004F	RM 138 TEACHERS LOUNGE	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	004F	RM 138 TEACHERS LOUNGE	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	004P	RM 138 TEACHERS LOUNGE	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	004P	RM 138 TEACHERS LOUNGE	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	005F	CAFE (ADULT)	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	005F	CAFE (ADULT)	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	005P	CAFE (ADULT)	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	005P	CAFE (ADULT)	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	006P	CAFE (CHILD)	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	006P	CAFE (CHILD)	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	007F	GYM HALLWAY BY RESTROOMS ADULT	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	007F	GYM HALLWAY BY RESTROOMS ADULT	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	007P	GYM HALLWAY BY RESTROOMS ADULT	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	007P	GYM HALLWAY BY RESTROOMS ADULT	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	008P	GYM HALLWAY BY RESTROOM CHILD	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	008P	GYM HALLWAY BY RESTROOM CHILD	

LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	123P	RM 341	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	123P	RM 341	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	124P	RM 341	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	124P	RM 341	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	125F	RM 340	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	125F	RM 340	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	125P	RM 340	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	125P	RM 340	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	126P	RM 340	
LCCA	Brockton	00440002	Brockton: Mary E. Baker School	Public School	126P	RM 340	

Copper is any result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

ANALYTENAME	RESULT	UNIT OF MEASURE	METHOD DETECTION LIMIT	ANALYTICAL METHOD	ANALYSIS LAB	LAB SAMPLE ID
COPPER	0.075	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-002
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-002
LEAD	0.0016	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-001
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-001
COPPER	0.064	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-004
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-004
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-003
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-003
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-006
COPPER	0.071	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-006
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-005
LEAD	0.0022	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-005
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-008
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-008
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-007
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-007
COPPER	0.026	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-010
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-010
COPPER	0.0025	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-009
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-009
COPPER	0.013	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-011
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-011
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-013
COPPER	0.028	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-013
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-012
COPPER	0.0076	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-012
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-014
COPPER	0.018	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-014

COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-016
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-016
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-015
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-015
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-018
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-018
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-017
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-017
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-019
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-019
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-021
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-021
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-020
COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-020
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-022
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-022
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-024
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-024
COPPER	0.19	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-023
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-023
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-026
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-026
COPPER	0.088	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-025
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-025
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-028
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-028
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-027
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-027
COPPER	0.19	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-029
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-029

LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-031
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-031
COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-030
LEAD	0.0016	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-030
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-033
COPPER	0.19	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-033
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-032
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-032
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-034
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-034
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-036
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-036
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-035
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-035
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-038
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-038
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-037
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-037
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-039
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-039
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-041
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-041
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-040
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-040
COPPER	0.025	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-043
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-043
COPPER	0.013	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-042
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-042
COPPER	0.020	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-044
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-044

COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-046
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-046
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-045
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-045
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-047
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-047
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-049
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-049
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-048
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-048
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-051
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-051
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-050
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-050
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-052
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-052
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-054
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-054
COPPER	0.086	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-053
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-053
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-056
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-056
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-055
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-055
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-058
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-058
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-057
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-057
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-060
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-060

COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-059
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-059
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-061
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-061
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-063
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-063
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-062
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-062
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-064
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-064
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-066
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-066
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-065
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-065
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-067
LEAD	0.0019	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-067
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-069
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-069
COPPER	0.20	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-068
LEAD	0.0014	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-068
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-070
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-070
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-072
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-072
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-071
LEAD	0.0031	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-071
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-073
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-073
COPPER	0.026	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-075
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-075

LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-074
COPPER	0.013	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-074
COPPER	0.026	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-077
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-077
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-076
COPPER	0.021	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-076
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-079
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-079
COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-078
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-078
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-080
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-080
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-082
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-082
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-081
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-081
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-083
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-083
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-085
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-085
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-084
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-084
COPPER	0.20	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-086
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-086
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-088
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-088
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-087
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-087
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-089
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-089

COPPER	0.19	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-091
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-091
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-090
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-090
COPPER	0.21	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-092
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-092
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-094
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-094
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-093
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-093
COPPER	0.22	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-095
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-095
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-097
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-097
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-096
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-096
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-098
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-098
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-100
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-100
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-099
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-099
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-101
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-101
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-103
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-103
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-102
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-102
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-104
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-104

COPPER	0.022	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-106
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-106
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-105
COPPER	0.0014	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-105
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-107
COPPER	0.0080	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-107
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-109
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-109
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-108
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-108
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-111
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-111
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-110
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-110
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-113
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-113
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-112
COPPER	0.097	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-112
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-115
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-115
COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-114
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-114
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-116
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-116
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-118
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-118
COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-117
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-117
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-119
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-119

COPPER	0.18	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-121
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-121
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-120
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-120
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-122
LEAD	0.0011	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-122
COPPER	0.19	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-124
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-124
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-123
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-123
COPPER	0.033	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-125
LEAD	0.0024	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-125
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-127
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-127
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-126
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-126
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-128
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-128
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-130
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-130
COPPER	0.086	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-129
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-129
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-131
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-131
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-133
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-133
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-132
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-132
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-134
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-134

COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-136
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-136
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-135
LEAD	0.0036	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-135
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-137
COPPER	0.20	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-137
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-139
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-139
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-138
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-138
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-140
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-140
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-142
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-142
COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-141
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-141
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-143
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-143
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-145
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-145
COPPER	0.085	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-144
LEAD	0.0018	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-144
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-146
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-146
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-148
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-148
COPPER	0.096	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-147
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-147
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-149
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-149

LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-151
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-151
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-150
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-150
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-153
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-153
COPPER	0.098	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-152
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-152
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-154
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-154
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-156
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-156
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-155
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-155
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-157
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-157
COPPER	0.025	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-159
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-159
COPPER	0.0098	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-158
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-158
COPPER	0.021	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-160
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-160
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-162
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-162
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-161
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-161
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-163
COPPER	0.24	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-163
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-165
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-165

COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-164
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-164
COPPER	0.18	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-166
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-166
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-168
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-168
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-167
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-167
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-169
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-169
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-171
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-171
COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-170
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-170
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-172
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-172
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-174
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-174
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-173
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-173
COPPER	0.21	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-175
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-175
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-177
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-177
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-176
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-176
COPPER	0.18	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-178
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-178
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-180
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-180

COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-179
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-179
COPPER	0.23	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-181
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-181
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-183
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-183
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-182
COPPER	0.097	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-182
COPPER	0.17	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-184
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-184
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-186
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-186
COPPER	0.13	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-185
LEAD	0.0013	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-185
COPPER	0.074	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-187
LEAD	0.0014	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-187
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-189
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-189
COPPER	0.11	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-188
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-188
COPPER	0.21	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-190
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-190
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-192
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-192
COPPER	0.12	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-191
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-191
COPPER	0.18	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-193
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-193
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-195
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-195

LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-194
COPPER	0.10	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-194
COPPER	0.19	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-196
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-196
COPPER	0.16	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-198
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-198
COPPER	0.14	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-197
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-197
LEAD	ND	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-199
COPPER	0.15	MG/L	0.0010	EPA 200.8	RI ANALYTICAL LABORATORIES INC	1611-26762-199

ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	TIME COLLECTION	REPORT DATE
	EARL N.	11/5/2016	08:14:00	16-Jan-17
	EARL N.	11/5/2016	08:14:00	16-Jan-17
	EARL N.	11/5/2016	08:13:00	16-Jan-17
	EARL N.	11/5/2016	08:13:00	16-Jan-17
	EARL N.	11/5/2016	08:15:00	16-Jan-17
	EARL N.	11/5/2016	08:15:00	16-Jan-17
	EARL N.	11/5/2016	08:14:00	16-Jan-17
	EARL N.	11/5/2016	08:14:00	16-Jan-17
	EARL N.	11/5/2016	08:18:00	16-Jan-17
	EARL N.	11/5/2016	08:18:00	16-Jan-17
	EARL N.	11/5/2016	08:17:00	16-Jan-17
	EARL N.	11/5/2016	08:17:00	16-Jan-17
	EARL N.	11/5/2016	08:11:00	16-Jan-17
	EARL N.	11/5/2016	08:11:00	16-Jan-17
	EARL N.	11/5/2016	08:10:00	16-Jan-17
	EARL N.	11/5/2016	08:10:00	16-Jan-17
	EARL N.	11/5/2016	08:23:00	16-Jan-17
	EARL N.	11/5/2016	08:23:00	16-Jan-17
	EARL N.	11/5/2016	08:21:00	16-Jan-17
	EARL N.	11/5/2016	08:21:00	16-Jan-17
	EARL N.	11/5/2016	08:22:00	16-Jan-17
	EARL N.	11/5/2016	08:22:00	16-Jan-17
	EARL N.	11/5/2016	08:27:00	16-Jan-17
	EARL N.	11/5/2016	08:27:00	16-Jan-17
	EARL N.	11/5/2016	08:26:00	16-Jan-17
	EARL N.	11/5/2016	08:26:00	16-Jan-17
	EARL N.	11/5/2016	08:26:00	16-Jan-17
	EARL N.	11/5/2016	08:26:00	16-Jan-17

	EARL N.	11/5/2016	08:30:00	16-Jan-17
	EARL N.	11/5/2016	08:30:00	16-Jan-17
	EARL N.	11/5/2016	08:29:00	16-Jan-17
	EARL N.	11/5/2016	08:29:00	16-Jan-17
	EARL N.	11/5/2016	08:32:00	16-Jan-17
	EARL N.	11/5/2016	08:32:00	16-Jan-17
	EARL N.	11/5/2016	08:32:00	16-Jan-17
	EARL N.	11/5/2016	08:32:00	16-Jan-17
	EARL N.	11/5/2016	08:32:00	16-Jan-17
	EARL N.	11/5/2016	08:32:00	16-Jan-17
	EARL N.	11/5/2016	08:32:00	16-Jan-17
	EARL N.	11/5/2016	08:36:00	16-Jan-17
	EARL N.	11/5/2016	08:36:00	16-Jan-17
	EARL N.	11/5/2016	08:35:00	16-Jan-17
	EARL N.	11/5/2016	08:35:00	16-Jan-17
	EARL N.	11/5/2016	08:38:00	16-Jan-17
	EARL N.	11/5/2016	08:38:00	16-Jan-17
	EARL N.	11/5/2016	08:39:00	16-Jan-17
	EARL N.	11/5/2016	08:39:00	16-Jan-17
	EARL N.	11/5/2016	08:38:00	16-Jan-17
	EARL N.	11/5/2016	08:38:00	16-Jan-17
	EARL N.	11/5/2016	08:41:00	16-Jan-17
	EARL N.	11/5/2016	08:41:00	16-Jan-17
	EARL N.	11/5/2016	08:40:00	16-Jan-17
	EARL N.	11/5/2016	08:40:00	16-Jan-17
	EARL N.	11/5/2016	08:44:00	16-Jan-17
	EARL N.	11/5/2016	08:44:00	16-Jan-17
	EARL N.	11/5/2016	08:43:00	16-Jan-17
	EARL N.	11/5/2016	08:43:00	16-Jan-17
	EARL N.	11/5/2016	08:43:00	16-Jan-17
	EARL N.	11/5/2016	08:43:00	16-Jan-17

	EARL N.	11/5/2016	08:46:00	16-Jan-17
	EARL N.	11/5/2016	08:46:00	16-Jan-17
	EARL N.	11/5/2016	08:45:00	16-Jan-17
	EARL N.	11/5/2016	08:45:00	16-Jan-17
	EARL N.	11/5/2016	08:49:00	16-Jan-17
	EARL N.	11/5/2016	08:49:00	16-Jan-17
	EARL N.	11/5/2016	08:48:00	16-Jan-17
	EARL N.	11/5/2016	08:48:00	16-Jan-17
	EARL N.	11/5/2016	08:48:00	16-Jan-17
	EARL N.	11/5/2016	08:48:00	16-Jan-17
	EARL N.	11/5/2016	08:51:00	16-Jan-17
	EARL N.	11/5/2016	08:51:00	16-Jan-17
	EARL N.	11/5/2016	08:50:00	16-Jan-17
	EARL N.	11/5/2016	08:50:00	16-Jan-17
	EARL N.	11/5/2016	08:53:00	16-Jan-17
	EARL N.	11/5/2016	08:53:00	16-Jan-17
	EARL N.	11/5/2016	08:52:00	16-Jan-17
	EARL N.	11/5/2016	08:52:00	16-Jan-17
	EARL N.	11/5/2016	08:52:00	16-Jan-17
	EARL N.	11/5/2016	08:52:00	16-Jan-17
	EARL N.	11/5/2016	08:55:00	16-Jan-17
	EARL N.	11/5/2016	08:55:00	16-Jan-17
	EARL N.	11/5/2016	08:54:00	16-Jan-17
	EARL N.	11/5/2016	08:54:00	16-Jan-17
	EARL N.	11/5/2016	08:57:00	16-Jan-17
	EARL N.	11/5/2016	08:57:00	16-Jan-17
	EARL N.	11/5/2016	08:56:00	16-Jan-17
	EARL N.	11/5/2016	08:56:00	16-Jan-17
	EARL N.	11/5/2016	08:56:00	16-Jan-17
	EARL N.	11/5/2016	08:56:00	16-Jan-17

	EARL N.	11/5/2016	08:59:00	16-Jan-17
	EARL N.	11/5/2016	08:59:00	16-Jan-17
	EARL N.	11/5/2016	08:57:00	16-Jan-17
	EARL N.	11/5/2016	08:57:00	16-Jan-17
	EARL N.	11/5/2016	08:57:00	16-Jan-17
	EARL N.	11/5/2016	08:57:00	16-Jan-17
	EARL N.	11/5/2016	09:01:00	16-Jan-17
	EARL N.	11/5/2016	09:01:00	16-Jan-17
	EARL N.	11/5/2016	09:00:00	16-Jan-17
	EARL N.	11/5/2016	09:00:00	16-Jan-17
	EARL N.	11/5/2016	09:03:00	16-Jan-17
	EARL N.	11/5/2016	09:03:00	16-Jan-17
	EARL N.	11/5/2016	09:02:00	16-Jan-17
	EARL N.	11/5/2016	09:02:00	16-Jan-17
	EARL N.	11/5/2016	09:02:00	16-Jan-17
	EARL N.	11/5/2016	09:02:00	16-Jan-17
	EARL N.	11/5/2016	09:05:00	16-Jan-17
	EARL N.	11/5/2016	09:05:00	16-Jan-17
	EARL N.	11/5/2016	09:04:00	16-Jan-17
	EARL N.	11/5/2016	09:04:00	16-Jan-17
	EARL N.	11/5/2016	09:08:00	16-Jan-17
	EARL N.	11/5/2016	09:08:00	16-Jan-17
	EARL N.	11/5/2016	09:07:00	16-Jan-17
	EARL N.	11/5/2016	09:07:00	16-Jan-17
	EARL N.	11/5/2016	09:09:00	16-Jan-17
	EARL N.	11/5/2016	09:09:00	16-Jan-17
	EARL N.	11/5/2016	09:08:00	16-Jan-17
	EARL N.	11/5/2016	09:08:00	16-Jan-17
	EARL N.	11/5/2016	09:12:00	16-Jan-17
	EARL N.	11/5/2016	09:12:00	16-Jan-17

	EARL N.	11/5/2016	09:11:00	16-Jan-17
	EARL N.	11/5/2016	09:11:00	16-Jan-17
	EARL N.	11/5/2016	09:11:00	16-Jan-17
	EARL N.	11/5/2016	09:11:00	16-Jan-17
	EARL N.	11/5/2016	09:14:00	16-Jan-17
	EARL N.	11/5/2016	09:14:00	16-Jan-17
	EARL N.	11/5/2016	09:13:00	16-Jan-17
	EARL N.	11/5/2016	09:13:00	16-Jan-17
	EARL N.	11/5/2016	09:13:00	16-Jan-17
	EARL N.	11/5/2016	09:13:00	16-Jan-17
	EARL N.	11/5/2016	09:16:00	16-Jan-17
	EARL N.	11/5/2016	09:16:00	16-Jan-17
	EARL N.	11/5/2016	09:15:00	16-Jan-17
	EARL N.	11/5/2016	09:15:00	16-Jan-17
	EARL N.	11/5/2016	09:15:00	16-Jan-17
	EARL N.	11/5/2016	09:15:00	16-Jan-17
	EARL N.	11/5/2016	09:19:00	16-Jan-17
	EARL N.	11/5/2016	09:19:00	16-Jan-17
	EARL N.	11/5/2016	09:18:00	16-Jan-17
	EARL N.	11/5/2016	09:18:00	16-Jan-17
	EARL N.	11/5/2016	09:18:00	16-Jan-17
	EARL N.	11/5/2016	09:18:00	16-Jan-17
	EARL N.	11/5/2016	09:21:00	16-Jan-17
	EARL N.	11/5/2016	09:21:00	16-Jan-17
	EARL N.	11/5/2016	09:20:00	16-Jan-17
	EARL N.	11/5/2016	09:20:00	16-Jan-17
	EARL N.	11/5/2016	09:20:00	16-Jan-17
	EARL N.	11/5/2016	09:20:00	16-Jan-17
	EARL N.	11/5/2016	09:25:00	16-Jan-17
	EARL N.	11/5/2016	09:25:00	16-Jan-17

	EARL N.	11/5/2016	09:24:00	16-Jan-17
	EARL N.	11/5/2016	09:24:00	16-Jan-17
	EARL N.	11/5/2016	09:25:00	16-Jan-17
	EARL N.	11/5/2016	09:25:00	16-Jan-17
	EARL N.	11/5/2016	09:24:00	16-Jan-17
	EARL N.	11/5/2016	09:24:00	16-Jan-17
	EARL N.	11/5/2016	09:28:00	16-Jan-17
	EARL N.	11/5/2016	09:28:00	16-Jan-17
	EARL N.	11/5/2016	09:27:00	16-Jan-17
	EARL N.	11/5/2016	09:27:00	16-Jan-17
	EARL N.	11/5/2016	09:27:00	16-Jan-17
	EARL N.	11/5/2016	09:27:00	16-Jan-17
	EARL N.	11/5/2016	09:29:00	16-Jan-17
	EARL N.	11/5/2016	09:29:00	16-Jan-17
	EARL N.	11/5/2016	09:28:00	16-Jan-17
	EARL N.	11/5/2016	09:28:00	16-Jan-17
	EARL N.	11/5/2016	09:28:00	16-Jan-17
	EARL N.	11/5/2016	10:27:00	16-Jan-17
	EARL N.	11/5/2016	10:27:00	16-Jan-17
	EARL N.	11/5/2016	10:26:00	16-Jan-17
	EARL N.	11/5/2016	10:26:00	16-Jan-17
	EARL N.	11/5/2016	10:26:00	16-Jan-17
	EARL N.	11/5/2016	10:26:00	16-Jan-17
	EARL N.	11/5/2016	10:32:00	16-Jan-17
	EARL N.	11/5/2016	10:32:00	16-Jan-17
	EARL N.	11/5/2016	10:31:00	16-Jan-17
	EARL N.	11/5/2016	10:31:00	16-Jan-17
	EARL N.	11/5/2016	10:31:00	16-Jan-17
	EARL N.	11/5/2016	10:31:00	16-Jan-17

	EARL N.	11/5/2016	10:35:00	16-Jan-17
	EARL N.	11/5/2016	10:35:00	16-Jan-17
	EARL N.	11/5/2016	10:34:00	16-Jan-17
	EARL N.	11/5/2016	10:34:00	16-Jan-17
	EARL N.	11/5/2016	10:34:00	16-Jan-17
	EARL N.	11/5/2016	10:34:00	16-Jan-17
	EARL N.	11/5/2016	10:38:00	16-Jan-17
	EARL N.	11/5/2016	10:38:00	16-Jan-17
	EARL N.	11/5/2016	10:37:00	16-Jan-17
	EARL N.	11/5/2016	10:37:00	16-Jan-17
	EARL N.	11/5/2016	10:37:00	16-Jan-17
	EARL N.	11/5/2016	10:37:00	16-Jan-17
	EARL N.	11/5/2016	10:43:00	16-Jan-17
	EARL N.	11/5/2016	10:43:00	16-Jan-17
	EARL N.	11/5/2016	10:42:00	16-Jan-17
	EARL N.	11/5/2016	10:42:00	16-Jan-17
	EARL N.	11/5/2016	10:42:00	16-Jan-17
	EARL N.	11/5/2016	10:46:00	16-Jan-17
	EARL N.	11/5/2016	10:46:00	16-Jan-17
	EARL N.	11/5/2016	10:45:00	16-Jan-17
	EARL N.	11/5/2016	10:45:00	16-Jan-17
	EARL N.	11/5/2016	10:45:00	16-Jan-17
	EARL N.	11/5/2016	10:45:00	16-Jan-17
	EARL N.	11/5/2016	10:49:00	16-Jan-17
	EARL N.	11/5/2016	10:49:00	16-Jan-17
	EARL N.	11/5/2016	10:48:00	16-Jan-17
	EARL N.	11/5/2016	10:48:00	16-Jan-17
	EARL N.	11/5/2016	10:48:00	16-Jan-17
	EARL N.	11/5/2016	10:48:00	16-Jan-17

	EARL N.	11/5/2016	10:52:00	16-Jan-17
	EARL N.	11/5/2016	10:52:00	16-Jan-17
	EARL N.	11/5/2016	10:51:00	16-Jan-17
	EARL N.	11/5/2016	10:51:00	16-Jan-17
	EARL N.	11/5/2016	10:51:00	16-Jan-17
	EARL N.	11/5/2016	10:51:00	16-Jan-17
	EARL N.	11/5/2016	10:56:00	16-Jan-17
	EARL N.	11/5/2016	10:56:00	16-Jan-17
	EARL N.	11/5/2016	10:55:00	16-Jan-17
	EARL N.	11/5/2016	10:55:00	16-Jan-17
	EARL N.	11/5/2016	10:57:00	16-Jan-17
	EARL N.	11/5/2016	10:57:00	16-Jan-17
	EARL N.	11/5/2016	10:54:00	16-Jan-17
	EARL N.	11/5/2016	10:54:00	16-Jan-17
	EARL N.	11/5/2016	10:59:00	16-Jan-17
	EARL N.	11/5/2016	10:59:00	16-Jan-17
	EARL N.	11/5/2016	10:58:00	16-Jan-17
	EARL N.	11/5/2016	10:58:00	16-Jan-17
	EARL N.	11/5/2016	11:02:00	16-Jan-17
	EARL N.	11/5/2016	11:02:00	16-Jan-17
	EARL N.	11/5/2016	11:01:00	16-Jan-17
	EARL N.	11/5/2016	11:01:00	16-Jan-17
	EARL N.	11/5/2016	11:01:00	16-Jan-17
	EARL N.	11/5/2016	11:01:00	16-Jan-17
	EARL N.	11/5/2016	11:04:00	16-Jan-17
	EARL N.	11/5/2016	11:04:00	16-Jan-17
	EARL N.	11/5/2016	11:03:00	16-Jan-17
	EARL N.	11/5/2016	11:03:00	16-Jan-17
	EARL N.	11/5/2016	11:03:00	16-Jan-17
	EARL N.	11/5/2016	11:03:00	16-Jan-17

	EARL N.	11/5/2016	11:20:00	16-Jan-17
	EARL N.	11/5/2016	11:20:00	16-Jan-17
	EARL N.	11/5/2016	11:18:00	16-Jan-17
	EARL N.	11/5/2016	11:18:00	16-Jan-17
	EARL N.	11/5/2016	11:18:00	16-Jan-17
	EARL N.	11/5/2016	11:18:00	16-Jan-17
	EARL N.	11/5/2016	11:24:00	16-Jan-17
	EARL N.	11/5/2016	11:24:00	16-Jan-17
	EARL N.	11/5/2016	11:21:00	16-Jan-17
	EARL N.	11/5/2016	11:21:00	16-Jan-17
	EARL N.	11/5/2016	11:21:00	16-Jan-17
	EARL N.	11/5/2016	11:21:00	16-Jan-17
	EARL N.	11/5/2016	11:27:00	16-Jan-17
	EARL N.	11/5/2016	11:27:00	16-Jan-17
	EARL N.	11/5/2016	11:26:00	16-Jan-17
	EARL N.	11/5/2016	11:26:00	16-Jan-17
	EARL N.	11/5/2016	11:26:00	16-Jan-17
	EARL N.	11/5/2016	11:30:00	16-Jan-17
	EARL N.	11/5/2016	11:30:00	16-Jan-17
	EARL N.	11/5/2016	11:29:00	16-Jan-17
	EARL N.	11/5/2016	11:29:00	16-Jan-17
	EARL N.	11/5/2016	11:29:00	16-Jan-17
	EARL N.	11/5/2016	11:29:00	16-Jan-17
	EARL N.	11/5/2016	11:32:00	16-Jan-17
	EARL N.	11/5/2016	11:32:00	16-Jan-17
	EARL N.	11/5/2016	11:31:00	16-Jan-17
	EARL N.	11/5/2016	11:31:00	16-Jan-17
	EARL N.	11/5/2016	11:31:00	16-Jan-17
	EARL N.	11/5/2016	11:31:00	16-Jan-17

	EARL N.	11/5/2016	11:35:00	16-Jan-17
	EARL N.	11/5/2016	11:35:00	16-Jan-17
	EARL N.	11/5/2016	11:34:00	16-Jan-17
	EARL N.	11/5/2016	11:34:00	16-Jan-17
	EARL N.	11/5/2016	11:34:00	16-Jan-17
	EARL N.	11/5/2016	11:34:00	16-Jan-17
	EARL N.	11/5/2016	11:38:00	16-Jan-17
	EARL N.	11/5/2016	11:38:00	16-Jan-17
	EARL N.	11/5/2016	11:37:00	16-Jan-17
	EARL N.	11/5/2016	11:37:00	16-Jan-17
	EARL N.	11/5/2016	11:37:00	16-Jan-17
	EARL N.	11/5/2016	11:37:00	16-Jan-17
	EARL N.	11/5/2016	11:40:00	16-Jan-17
	EARL N.	11/5/2016	11:40:00	16-Jan-17
	EARL N.	11/5/2016	11:39:00	16-Jan-17
	EARL N.	11/5/2016	11:39:00	16-Jan-17
	EARL N.	11/5/2016	11:39:00	16-Jan-17
	EARL N.	11/5/2016	11:43:00	16-Jan-17
	EARL N.	11/5/2016	11:43:00	16-Jan-17
	EARL N.	11/5/2016	11:42:00	16-Jan-17
	EARL N.	11/5/2016	11:42:00	16-Jan-17
	EARL N.	11/5/2016	11:42:00	16-Jan-17
	EARL N.	11/5/2016	11:42:00	16-Jan-17
	EARL N.	11/5/2016	11:45:00	16-Jan-17
	EARL N.	11/5/2016	11:45:00	16-Jan-17
	EARL N.	11/5/2016	11:44:00	16-Jan-17
	EARL N.	11/5/2016	11:44:00	16-Jan-17
	EARL N.	11/5/2016	11:44:00	16-Jan-17
	EARL N.	11/5/2016	11:44:00	16-Jan-17

	EARL N.	11/5/2016	13:33:00	16-Jan-17
	EARL N.	11/5/2016	13:33:00	16-Jan-17
	EARL N.	11/5/2016	13:32:00	16-Jan-17
	EARL N.	11/5/2016	13:32:00	16-Jan-17
	EARL N.	11/5/2016	12:44:00	16-Jan-17
	EARL N.	11/5/2016	12:44:00	16-Jan-17
	EARL N.	11/5/2016	12:43:00	16-Jan-17
	EARL N.	11/5/2016	12:43:00	16-Jan-17
	EARL N.	11/5/2016	12:43:00	16-Jan-17
	EARL N.	11/5/2016	12:43:00	16-Jan-17
	EARL N.	11/5/2016	12:43:00	16-Jan-17
	EARL N.	11/5/2016	12:46:00	16-Jan-17
	EARL N.	11/5/2016	12:46:00	16-Jan-17
	EARL N.	11/5/2016	12:45:00	16-Jan-17
	EARL N.	11/5/2016	12:45:00	16-Jan-17
	EARL N.	11/5/2016	12:45:00	16-Jan-17
	EARL N.	11/5/2016	12:45:00	16-Jan-17
	EARL N.	11/5/2016	12:51:00	16-Jan-17
	EARL N.	11/5/2016	12:51:00	16-Jan-17
	EARL N.	11/5/2016	12:50:00	16-Jan-17
	EARL N.	11/5/2016	12:50:00	16-Jan-17
	EARL N.	11/5/2016	12:50:00	16-Jan-17
	EARL N.	11/5/2016	12:50:00	16-Jan-17
	EARL N.	11/5/2016	12:54:00	16-Jan-17
	EARL N.	11/5/2016	12:54:00	16-Jan-17
	EARL N.	11/5/2016	12:53:00	16-Jan-17
	EARL N.	11/5/2016	12:53:00	16-Jan-17
	EARL N.	11/5/2016	12:53:00	16-Jan-17
	EARL N.	11/5/2016	12:53:00	16-Jan-17
	EARL N.	11/5/2016	12:57:00	16-Jan-17
	EARL N.	11/5/2016	12:57:00	16-Jan-17

	EARL N.	11/5/2016	12:56:00	16-Jan-17
	EARL N.	11/5/2016	12:56:00	16-Jan-17
	EARL N.	11/5/2016	12:56:00	16-Jan-17
	EARL N.	11/5/2016	12:56:00	16-Jan-17
	EARL N.	11/5/2016	12:59:00	16-Jan-17
	EARL N.	11/5/2016	12:59:00	16-Jan-17
	EARL N.	11/5/2016	12:58:00	16-Jan-17
	EARL N.	11/5/2016	12:58:00	16-Jan-17
	EARL N.	11/5/2016	12:58:00	16-Jan-17
	EARL N.	11/5/2016	12:58:00	16-Jan-17
	EARL N.	11/5/2016	12:58:00	16-Jan-17
	EARL N.	11/5/2016	13:02:00	16-Jan-17
	EARL N.	11/5/2016	13:02:00	16-Jan-17
	EARL N.	11/5/2016	13:01:00	16-Jan-17
	EARL N.	11/5/2016	13:01:00	16-Jan-17
	EARL N.	11/5/2016	13:01:00	16-Jan-17
	EARL N.	11/5/2016	13:01:00	16-Jan-17
	EARL N.	11/5/2016	13:04:00	16-Jan-17
	EARL N.	11/5/2016	13:04:00	16-Jan-17
	EARL N.	11/5/2016	13:03:00	16-Jan-17
	EARL N.	11/5/2016	13:03:00	16-Jan-17
	EARL N.	11/5/2016	13:03:00	16-Jan-17
	EARL N.	11/5/2016	13:03:00	16-Jan-17
	EARL N.	11/5/2016	13:06:00	16-Jan-17
	EARL N.	11/5/2016	13:06:00	16-Jan-17
	EARL N.	11/5/2016	13:05:00	16-Jan-17
	EARL N.	11/5/2016	13:05:00	16-Jan-17
	EARL N.	11/5/2016	13:05:00	16-Jan-17
	EARL N.	11/5/2016	13:05:00	16-Jan-17
	EARL N.	11/5/2016	13:08:00	16-Jan-17
	EARL N.	11/5/2016	13:08:00	16-Jan-17

	EARL N.	11/5/2016	13:07:00	16-Jan-17
	EARL N.	11/5/2016	13:07:00	16-Jan-17
	EARL N.	11/5/2016	13:07:00	16-Jan-17
	EARL N.	11/5/2016	13:07:00	16-Jan-17
	EARL N.	11/5/2016	13:10:00	16-Jan-17
	EARL N.	11/5/2016	13:10:00	16-Jan-17
	EARL N.	11/5/2016	13:09:00	16-Jan-17
	EARL N.	11/5/2016	13:09:00	16-Jan-17
	EARL N.	11/5/2016	13:09:00	16-Jan-17
	EARL N.	11/5/2016	13:09:00	16-Jan-17
	EARL N.	11/5/2016	13:09:00	16-Jan-17
	EARL N.	11/5/2016	13:14:00	16-Jan-17
	EARL N.	11/5/2016	13:14:00	16-Jan-17
	EARL N.	11/5/2016	13:13:00	16-Jan-17
	EARL N.	11/5/2016	13:13:00	16-Jan-17
	EARL N.	11/5/2016	13:13:00	16-Jan-17
	EARL N.	11/5/2016	13:13:00	16-Jan-17
	EARL N.	11/5/2016	13:16:00	16-Jan-17
	EARL N.	11/5/2016	13:16:00	16-Jan-17
	EARL N.	11/5/2016	13:15:00	16-Jan-17
	EARL N.	11/5/2016	13:15:00	16-Jan-17
	EARL N.	11/5/2016	13:15:00	16-Jan-17
	EARL N.	11/5/2016	13:15:00	16-Jan-17
	EARL N.	11/5/2016	13:18:00	16-Jan-17
	EARL N.	11/5/2016	13:18:00	16-Jan-17
	EARL N.	11/5/2016	13:17:00	16-Jan-17
	EARL N.	11/5/2016	13:17:00	16-Jan-17
	EARL N.	11/5/2016	13:17:00	16-Jan-17
	EARL N.	11/5/2016	13:17:00	16-Jan-17
	EARL N.	11/5/2016	13:20:00	16-Jan-17
	EARL N.	11/5/2016	13:20:00	16-Jan-17

	EARL N.	11/5/2016	13:19:00	16-Jan-17
	EARL N.	11/5/2016	13:19:00	16-Jan-17
	EARL N.	11/5/2016	13:19:00	16-Jan-17
	EARL N.	11/5/2016	13:19:00	16-Jan-17
	EARL N.	11/5/2016	13:22:00	16-Jan-17
	EARL N.	11/5/2016	13:22:00	16-Jan-17
	EARL N.	11/5/2016	13:21:00	16-Jan-17
	EARL N.	11/5/2016	13:21:00	16-Jan-17
	EARL N.	11/5/2016	13:21:00	16-Jan-17
	EARL N.	11/5/2016	13:21:00	16-Jan-17