

The results (column J) are reported in mg/l or parts per million. The action level for lead is any result greater than 0.015 mg/l. The action level for copper is any

PORTYPECO	CITYTOWN	ORG CODE	SCHOOL NAME	SCHOOL TYPE	LOCATION ID	SAMPLE LOCATION NAME	PLECOMM	ANALYTENAME
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	001F	SINK NURSE'S OFFICE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	001F	SINK NURSE'S OFFICE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	001P	SINK NURSE'S OFFICE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	001P	SINK NURSE'S OFFICE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	008F	BUBBLER GYM GIRL'S SIDE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	008F	BUBBLER GYM GIRL'S SIDE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	008P	BUBBLER GYM GIRL'S SIDE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	008P	BUBBLER GYM GIRL'S SIDE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	009P	BUBBLER HALL SIDE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	009P	BUBBLER HALL SIDE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	010F	CAFE BOTTLE HALL SIDE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	010F	CAFE BOTTLE HALL SIDE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	010P	CAFE BOTTLE HALL SIDE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	010P	CAFE BOTTLE HALL SIDE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	011P	BUBBLER CAFE WINDOW SIDE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	011P	BUBBLER CAFE WINDOW SIDE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	012F	BOTTLE FILLER CAFE WINDOW		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	012F	BOTTLE FILLER CAFE WINDOW		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	012P	BOTTLE FILLER CAFE WINDOW		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	012P	BOTTLE FILLER CAFE WINDOW		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	013F	KITCHEN KETTLE COLD		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	013F	KITCHEN KETTLE COLD		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	013P	KITCHEN KETTLE COLD		LEAD

LCCA	Brockton	00440410	Brockton: North Middle School	Public School	013P	KITCHEN KETTLE COLD		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	014F	KITCHEN PREP SINK		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	014F	KITCHEN PREP SINK		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	014P	KITCHEN PREP SINK		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	014P	KITCHEN PREP SINK		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	015F	PREP SINK CLOSEST TO OUTSIDE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	015F	PREP SINK CLOSEST TO OUTSIDE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	015P	PREP SINK CLOSEST TO OUTSIDE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	015P	PREP SINK CLOSEST TO OUTSIDE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	016F	KITCHEN PREP SINK DOUBLE BOWL		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	016F	KITCHEN PREP SINK DOUBLE BOWL		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	016P	KITCHEN PREP SINK DOUBLE BOWL		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	016P	KITCHEN PREP SINK DOUBLE BOWL		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	018F	BUBBLER BOY'S LOCKER ROOM		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	018F	BUBBLER BOY'S LOCKER ROOM		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	018P	BUBBLER BOY'S LOCKER ROOM		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	018P	BUBBLER BOY'S LOCKER ROOM		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	019F	BUBBLER GYM BOY'S SIDE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	019F	BUBBLER GYM BOY'S SIDE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	019P	BUBBLER GYM BOY'S SIDE		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	019P	BUBBLER GYM BOY'S SIDE		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	020F	CLASSROOM FAUCET ROOM 111		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	020F	CLASSROOM FAUCET ROOM 111		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	020P	CLASSROOM FAUCET ROOM 111		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	020P	CLASSROOM FAUCET ROOM 111		COPPER

LCCA	Brockton	00440410	Brockton: North Middle School	Public School	023F	BUBBLER ACROSS FROM RM 104		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	023F	BUBBLER ACROSS FROM RM 104		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	023P	BUBBLER ACROSS FROM RM 104		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	023P	BUBBLER ACROSS FROM RM 104		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	024F	BUBBLER ACROSS FROM RM 101		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	024F	BUBBLER ACROSS FROM RM 101		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	024P	BUBBLER ACROSS FROM RM 101		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	024P	BUBBLER ACROSS FROM RM 101		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	025F	FAUCET STAFF LOUNGE LIBRARY		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	025F	FAUCET STAFF LOUNGE LIBRARY		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	025P	FAUCET STAFF LOUNGE LIBRARY		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	025P	FAUCET STAFF LOUNGE LIBRARY		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	027F	HOME ECONOMICS RM 221		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	027F	HOME ECONOMICS RM 221		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	027P	HOME ECONOMICS RM 221		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	027P	HOME ECONOMICS RM 221		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	028F	HOME ECONOMICS RM 221		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	028F	HOME ECONOMICS RM 221		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	028P	HOME ECONOMICS RM 221		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	028P	HOME ECONOMICS RM 221		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	031F	CLASSRM FAUCET RM 221: WINDOW		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	031F	CLASSRM FAUCET RM 221: WINDOW		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	031P	CLASSRM FAUCET RM 221: WINDOW		LEAD
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	031P	CLASSRM FAUCET RM 221: WINDOW		COPPER
LCCA	Brockton	00440410	Brockton: North Middle School	Public School	033F	CLASSROOM FAUCET RM 209		LEAD

result greater than 1.3 mg/l. "ND" stands for non-detect: the contaminant was not detected above the MDL.

RESULT	UNIT OF MEASURE	METHOD DETECTION LIMIT	ANALYTICAL METHOD	ANALYSIS LABEL	LAB SAMPLE ID	ANALYSIS COMMENTS	SAMPLER NAME	SAMPLE COLLECTION DATE	TIME COLLECTION
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-002		DAVID DEROUEN	12/3/2016	07:44:00
0.084	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-002		DAVID DEROUEN	12/3/2016	07:44:00
0.0048	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-001		DAVID DEROUEN	12/3/2016	07:43:00
0.096	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-001		DAVID DEROUEN	12/3/2016	07:43:00
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-004		DAVID DEROUEN	12/3/2016	07:00:00
0.091	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-004		DAVID DEROUEN	12/3/2016	07:00:00
0.0016	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-003		DAVID DEROUEN	12/3/2016	06:59:00
0.082	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-003		DAVID DEROUEN	12/3/2016	06:59:00
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-005		DAVID DEROUEN	12/3/2016	07:08:00
0.12	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-005		DAVID DEROUEN	12/3/2016	07:08:00
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-007		DAVID DEROUEN	12/3/2016	07:09:00
0.073	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-007		DAVID DEROUEN	12/3/2016	07:09:00
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-006		DAVID DEROUEN	12/3/2016	07:08:00
0.20	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-006		DAVID DEROUEN	12/3/2016	07:08:00
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-008		DAVID DEROUEN	12/3/2016	07:10:00
0.029	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-008		DAVID DEROUEN	12/3/2016	07:10:00
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-010		DAVID DEROUEN	12/3/2016	07:11:00
0.017	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-010		DAVID DEROUEN	12/3/2016	07:11:00
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-009		DAVID DEROUEN	12/3/2016	07:11:00
0.059	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-009		DAVID DEROUEN	12/3/2016	07:11:00
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-012		DAVID DEROUEN	12/3/2016	07:14:00
0.095	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-012		DAVID DEROUEN	12/3/2016	07:14:00
0.0025	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-011		DAVID DEROUEN	12/3/2016	07:13:00

0.086	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-011		DAVID DEROUEN	12/3/2016	07:13:00
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-014		DAVID DEROUEN	12/3/2016	07:16:00
0.072	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-014		DAVID DEROUEN	12/3/2016	07:16:00
0.0056	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-013		DAVID DEROUEN	12/3/2016	07:15:00
0.11	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-013		DAVID DEROUEN	12/3/2016	07:15:00
0.074	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-016		DAVID DEROUEN	12/3/2016	07:17:00
0.80	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-016		DAVID DEROUEN	12/3/2016	07:17:00
4.28	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-015		DAVID DEROUEN	12/3/2016	07:16:00
51.2	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-015		DAVID DEROUEN	12/3/2016	07:16:00
0.0047	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-018		DAVID DEROUEN	12/3/2016	07:17:00
0.13	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-018		DAVID DEROUEN	12/3/2016	07:17:00
0.34	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-017		DAVID DEROUEN	12/3/2016	07:16:00
1.1	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-017		DAVID DEROUEN	12/3/2016	07:16:00
0.024	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-020		DAVID DEROUEN	12/3/2016	07:54:00
0.24	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-020		DAVID DEROUEN	12/3/2016	07:54:00
0.032	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-019		DAVID DEROUEN	12/3/2016	07:53:00
0.26	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-019		DAVID DEROUEN	12/3/2016	07:53:00
0.0011	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-022		DAVID DEROUEN	12/3/2016	07:04:00
0.094	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-022		DAVID DEROUEN	12/3/2016	07:04:00
0.0026	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-021		DAVID DEROUEN	12/3/2016	07:03:00
0.098	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-021		DAVID DEROUEN	12/3/2016	07:03:00
0.0037	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-024		DAVID DEROUEN	12/3/2016	07:59:00
0.028	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-024		DAVID DEROUEN	12/3/2016	07:59:00
0.14	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-023		DAVID DEROUEN	12/3/2016	07:58:00
0.55	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-023		DAVID DEROUEN	12/3/2016	07:58:00

ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-026		DAVID DEROUEN	12/3/2016	06:48:00
0.086	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-026		DAVID DEROUEN	12/3/2016	06:48:00
ND	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-025		DAVID DEROUEN	12/3/2016	06:47:00
0.12	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-025		DAVID DEROUEN	12/3/2016	06:47:00
0.0014	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-028		DAVID DEROUEN	12/3/2016	06:51:00
0.14	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-028		DAVID DEROUEN	12/3/2016	06:51:00
0.010	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-027		DAVID DEROUEN	12/3/2016	06:50:00
0.21	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-027		DAVID DEROUEN	12/3/2016	06:50:00
0.0040	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-030		DAVID DEROUEN	12/3/2016	08:03:00
0.70	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-030		DAVID DEROUEN	12/3/2016	08:03:00
0.0052	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-029		DAVID DEROUEN	12/3/2016	08:02:00
0.40	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-029		DAVID DEROUEN	12/3/2016	08:02:00
0.019	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-032		DAVID DEROUEN	12/3/2016	07:34:00
0.13	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-032		DAVID DEROUEN	12/3/2016	07:34:00
0.24	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-031		DAVID DEROUEN	12/3/2016	07:33:00
1.3	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-031		DAVID DEROUEN	12/3/2016	07:33:00
0.041	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-034		DAVID DEROUEN	12/3/2016	07:39:00
0.21	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-034		DAVID DEROUEN	12/3/2016	07:39:00
0.12	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-033		DAVID DEROUEN	12/3/2016	07:38:00
0.75	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-033		DAVID DEROUEN	12/3/2016	07:38:00
0.0014	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-036		DAVID DEROUEN	12/3/2016	07:30:00
0.10	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-036		DAVID DEROUEN	12/3/2016	07:30:00
0.018	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-035		DAVID DEROUEN	12/3/2016	07:29:00
0.10	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-035		DAVID DEROUEN	12/3/2016	07:29:00
0.0085	MG/L	0.0010	EPA 200.8	RI ANALYT	1612-28998-038		DAVID DEROUEN	12/3/2016	08:05:00

